

Certificate of Compliance




*Additional Information:
(Cont.)*

HORSEPOWER RATINGS

| Current Volts | Alternating | | | | | | | | | Direct | | |
|------------------|-------------|---|------|-----|---|------|-----|---|------|--------|-----|-----|
| | 240 | | | 480 | | | 600 | | | 125 | 250 | 600 |
| Phases | 1 | 2 | 3 | 1 | 2 | 3 | 1 | 2 | 3 | - | - | - |
| Wires | 2 | 4 | 3 | 2 | 4 | 3 | 2 | 4 | 3 | 2 | 2 | 2 |
| Cat. No. | | | | | | | | | | | | |
| H-267 | | | | | | | 50 | | | | | 50 |
| H-268 | | | | | | | 50 | | | | | 50 |
| H-328 | 50 | | 100 | | | | | | | | | |
| | | | 250+ | | | | | | | | 50 | |
| H-367 | | | | | | 200 | 50 | | 250 | | | |
| | | | | | | 500+ | | | 500+ | | | 50 |
| H-368 | | | | | | 200 | 50 | | 250 | | | 50 |
| | | | | | | 500+ | | | 500+ | | | |
| HU-227 | 50 | | | | | | | | | | 50 | |
| HU-228 | 50 | | | | | | | | | | 50 | |
| HU-267 | | | | | | | 50 | | | | | 50 |
| HU-268 | | | | | | | 50 | | | | | 50 |
| HU-327 | 50 | | 250 | | | | | | | | 50 | |
| HU-328 | 50 | | 250 | | | | | | | | 50 | |
| HU-367 | | | | | | 500 | 50 | | 500 | | | 50 |
| HU-368 | | | | | | | 50 | | 500 | | | 50 |

+ - Indicates that marking is required to use fuses with appropriate time delay characteristics.

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers;  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney
Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus/>