



## CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 080301-E154828

ISSUE DATE: March 8, 2001

Page 1 of 3

Issued to: Square D Company  
1501 South University Blvd.  
Middletown, OH. 45044

Report Reference: E154828, February 5, 1985


This is to Certify that  
representative samples of: Enclosed Switches, catalog numbers H (fused) and HU (unfused), -225, -265,  
-325, -365, -425, -465, -226, -266, -326, -366, -426, -466, with or without suffix  
letters.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)  
indicated on this Certificate.

Standard(s) for Safety: UL 98, Enclosed Switches


Additional Information: See Addendum

Only those products bearing the UL Listing Mark should be considered as being covered by  
UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control  
number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate  
UL Directory.

**LOOK FOR THE UL LISTING MARK ON THE PRODUCT**

Engineer:   
Tom Skibbs  
Underwriters Laboratories Inc.

Review Engineer:   
Jeff Hidaka  
Underwriters Laboratories Inc.



## CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 080301-E154828  
ISSUE DATE: March 8, 2001

Page 2 of 3

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

**Ratings:**


Curent: 400A and 600A  
Voltage: 600Vac, 250Vdc, maximum


**Short Circuit:**

When used with class R or J fuses, fused switches are suitable for use on circuits capable of delivering not more than 200,000 rms sym. amperes.

When protected by class R fuses rated (400A or 600A), unfused switches are suitable for use on circuits capable of delivering not more than 200,000 rms sym. amperes.

When protected by other than class R fuses rated (continuous current rating of switch), unfused switches are suitable for use on circuits capable of delivering not more than 10,000 rms sym. amperes.

Engineer:   
Tom Skibbs  
Underwriters Laboratories Inc.

Review Engineer:   
Jeff Hidaka  
Underwriters Laboratories Inc.




**CERTIFICATE OF COMPLIANCE - ADDENDUM**


CERTIFICATE NUMBER: 080301-E154828  
 ISSUE DATE: March 8, 2001

Page 3 of 3

**Horsepower Ratings (+ indicates maximum HP rating)**

Current Volts	Alternating									Direct		
	240			480			600			125	250	600
Phases	1	2	3	1	2	3	1	2	3	-	-	-
Wires	2	4	3	2	4	3	2	4	3	2	2	2
Cat. No.												
H266N						150, 400+						
H226, -N			75, 200+									
HU226N			200									
H326, -N			75, 200+									
H366, -N			75, 200+			150, 400+			200, 500+			
HU366, -N			200			400			500			
H266						150, 400+						
H265N						100, 250+					50	
H225											50	
H225N			50, 125+									
H265						100, 250+					50	
H325, -N			50, 125+								50	
H365						100, 250+			125, 350+		50	
H365N						100, 250+			125, 350+			
HU225											50	
HU265N						250					50	
HU265											50	
HU365			125			250			350		50	
H425		50										

Engineer:   
 Tom Skibbs  
 Underwriters Laboratories Inc.

Review Engineer:   
 Jeff Hidaka  
 Underwriters Laboratories Inc.