

Certificate of Compliance

Certificate: 70074793 **Master Contract:** 153555 (LR 29971)

Issued to: Schneider Electric USA, Inc.

Square D 3700 6th St SW

Cedar Rapids, Iowa 52404

USA

Attention: Manuel Salinas

The products listed below are eligible to bear the CSA Mark shown



Issued by: Ronald Tateishi

Ronald Tateishi

PRODUCTS

CLASS 1432 02 - CIRCUIT BREAKERS - Arc Fault Circuit Interrupters CLASS 1451 01 - GROUND FAULT DEVICES - Circuit Interrupters

Combined circuit breaker and ground fault/arc fault circuit interrupters, Class A, Types QO, QOB and QOP, Cat. No. Suffix DF, Series 3, single pole, 15 and 20A, 120V ac.

Notes:

- 1. These circuit breakers are Certified for use only in enclosures where the suitability has been determined by CSA Group.
- 2. These circuit breakers are suitable for use where the Canadian Electrical Code, Part I requires that a "Class A" interrupter be used.
- 3. These circuit breakers provide both series and parallel arc fault protection.
- 4. The Cat. Nos. QO(B)115DF, QO(B)120DF, QO115PDF, QO120PDF, QO(B)115FRDF and QO(B)120FRDF may be marked with an interrupting rating of 10,000 rms symmetrical amperes, 120V ac.
- 5. The Cat. Nos. QO(B)115VHDF, QO(B)120VHDF, QO115VHPDF, QO120VHPDF, QO(B)115FRVHDF and QO(B)120FRVHDF may be marked with an interrupting rating of 22,000 rms symmetrical amperes, 120V ac

DQD 507 Rev. 2012-05-22 Page 1



Certificate: 70074793 **Master Contract:** 153555 (LR 29971)

Project: 70093996 **Date Issued:** 2016-08-18

6. The Cat. Nos. QO(B)115FRDF, QO(B)120FRDF, QO(B)115FRVHDF and QO(B)120FRVHDF are field recorder versions of Series 3 with two microcontrollers integrated on the printed wiring board.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures

CSA Standard C22.2 No. 144.1 - Ground-Fault Circuit-Interrupters

CSA Standard C22.2 No. 270 - Arc Fault Protective devices



Supplement to Certificate of Compliance

Certificate: 70074793 **Master Contract:** 153555 (LR 29971)

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
70093996	2016-08-18	Diagnostic firmware change to address a field performance issue during extended low-voltage brownout conditions.
70088406	2016-07-27	Change in the R31 resistor from 301 ohms to 1 kohm and software revisions.
70074793	2016-04-29	Certification of combined MCCB and GFCI/AFCI, Type QO, Series 3.