



Certificate of Compliance

Certificate: 2661591 (LR 29971)

Master Contract: 153555

Project: 70027705

Date Issued: April 13, 2015

Issued to: Schneider Electric USA, Inc.

Square D
3700 6th St SW
Cedar Rapids, IA 52404
USA
Attention: Manuel Salinas

The products listed below are eligible to bear the CSA Mark shown



R. Tateishi

Issued by: R. Tateishi, P. Eng.

PRODUCTS

CLASS 1432 02 - CIRCUIT BREAKERS - Arc Fault Circuit Interrupters

Combined circuit breaker and arc fault circuit interrupter, Types QO and QOB, Series 1, 2-pole, 15 and 20A, 120/240V ac.

Notes:

1. These circuit breakers provide both series and parallel arc fault protection.
2. The Cat. Nos. QO(B)215CAFI and QO(B)220CAFI may be marked with an interrupting rating of 10,000 rms symmetrical amperes, 120/240V ac.
3. The Cat. Nos QO(B)215VHCAFI and QO(B)220VHCAFI may be marked with an interrupting rating of 22,000 rms symmetrical amperes, 120/240V ac.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures

TIL No. M-02A - Interim Requirements for Arc-Fault Circuit Interrupters



Supplement to Certificate of Compliance

Certificate: 2661591

Master Contract: 153555

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
70027705	Apr 13, 2015	Addition of an alternate stationary contact.
2661591	Nov 28, 2013	Original Certification.