



Certificate of Compliance

Certificate: 70046699

Master Contract: 153555 (LR 29971)

Project: 70101976

Date Issued: 2016-11-04

Issued to: Schneider Electric USA, Inc.
Square D
3700 6th St SW
Cedar Rapids, Iowa 52404
USA
Attention: Manuel Salinas

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Ronald Tateishi*
Ronald Tateishi

PRODUCTS

CLASS 1451 01 - GROUND FAULT DEVICES - Circuit Interrupters

Combined circuit breaker and ground fault interrupter, Class A, Type QO and QOB, Series 1, 3-pole, 15-50A, 208Y/120V ac.

Notes:

1. These devices are Certified for use only in enclosures where the suitability has been determined by CSA Group.
2. These devices are suitable for use where the Canadian Electrical Code, Part I requires that a "Class A" interrupter be used.
3. These devices may be provided with the following factory installed accessories; auxiliary switch, bell alarm switch, ring tongue connectors or lock off bracket, QOGFI2PAF.
4. These devices may bear high interrupting ratings, 10kA rms symmetrical amperes, 208Y/120V ac.



Certificate: 70046699

Project: 70101976

Master Contract: 153555 (LR 29971)

Date Issued: 2016-11-04

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures

CSA Standard C22.2 No. 144.1 - Ground-Fault Circuit-Interrupters



Supplement to Certificate of Compliance

Certificate: 70046699

Master Contract: 153555 (LR 29971)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70101976	2016-11-04	Addition of the description of the terminal cover which is used on the ring tongue terminal breakers.
70046699	2015-09-28	Certification of 3-pole, QO-GFCI