

Certificate of Compliance

Certificate Number 20090306 – E6294A
Report Reference E6294, 1988 January 08
Issue Date 2009 March 06

Page 1 of 1



Issued to: **SQUARE D CO**
1601 MERCER RD
LEXINGTON, KY 40511 USA

*This is to certify that
representative samples of*

Panelboards

Model Descriptions: Panelboards and enclosed panelboards, Type HOM.

*Have been investigated by Underwriters Laboratories Inc.® in accordance
with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety:

The basic standards used to investigate products in this category are ANSI/UL 67, "Panelboards" and CSA-C22.2 No. 29, "Panelboards and Enclosed Panelboards."


Additional Information:

Ratings:

Main lug - 225 maximum amperes, 120/240 maximum volts.

Main breaker - 225 maximum amperes, 120/240 maximum volts.

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by:

Jim Larin

Jim Larin, Customer Service Specialist

Underwriters Laboratories Inc.

Reviewed by:

Thomas Skibbs

Thomas Skibbs, Staff Engineering Associate

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL

For questions in The United States of America you may call 1-877-UL-HELPS.