

Northbrook, Illinois • (847) 272-8800
Melville, New York • (631) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 817-5500

 **Underwriters Laboratories Inc.®**
CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 071002-E6294D

ISSUE DATE: July 10, 2002

Page 1 of 1

Issued to: Square D Company
1601 Mercer Rd.
Lexington, KY. 40511

Report Reference: E6294, November 24, 1982

This is to Certify that
representative samples of: Class 1130, Enclosed Panelboards. Type QO, Three Phase


Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 67, Panelboards

Additional Information: **Ratings:**

<u>AMPS</u>	<u>VOLTS</u>
100	208Y/120V ac, 3-PH, 4W
125	240/120V ac, 3-PH, 4W
200	240V ac, 3-PH, 3W
225	

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: *Susan Amir*
Susan Amir, Project Handler III
Underwriters Laboratories Inc.

Review Engineer: *Tom Skibbs*
Tom Skibbs, Lead Engineering Associate
Underwriters Laboratories Inc.