

Northbrook, Illinois • (847) 272-8800
Melville, New York • (516) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 817-5500



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 260401-E48340B

ISSUE DATE: April 26, 2001

Page 1 of 1

Issued to: Square D Company
3700 6th Street S.W.
Cedar Rapids, IA 52404-3069, USA

Report Reference: E48340, February 10, 1993


This is to Certify that representative samples of: Molded Case Circuit Breakers and Ground Fault Interrupter Type HOM Series 1

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 489, Molded Case Circuit Breakers and Circuit Breaker Enclosures

Additional Information: These are two pole circuit breakers and ground fault interrupters, rated from 15A through 50A.
Current Interrupting Rating is as follows:
10,000A, 120/240 Vac, 1phase, 60 Hz.
Uses wires rated as follows:
75 Deg.C only.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: *Lawrence R. Smith*
Lawrence R. Smith, Staff Eng. Associate
Underwriters Laboratories Inc.

Review Engineer: *R. Hames*
Bob Hames, Sr. Staff Engineer
Underwriters Laboratories Inc.