

IEC

IECEE
CB
SCHEME

Ref. Certif. No.

CN47537

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Auxiliary Contact Blocks

Name and address of the applicant

Schneider Electric Industries SAS
31 rue Pierre Mendès-France 38320 EYBENS, France

Name and address of the manufacturer

Schneider Electric a. s.
Cizovska 447 - 39701 Pisek - Czech Republic

Name and address of the factory

Schneider Electric a. s.
Cizovska 447- 397 01 Pisek – Czech Republic

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp:8kV; Ui:690V; Ith:12A;
Ue/Ie:AC-15:AC220-240V/6A,380-415V/4A,500V/2A,690V/1
A; IP20

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

VZ 7, VZ 20

Additional information (if necessary may also be reported on page 2)

IEC 60947-5-1:2016(4th Edition)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2018CQC-083937

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>



Date: Aug.09,2019

Signature:

A handwritten signature in black ink, appearing to be '陆梅' (Lu Mei).

Lu Mei

CB 0053624