

IEC**IECEE**

®

™

Ref. Certif. No.

CN72705

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Auxiliary Contact Blocks

Name and address of the applicant

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the factory

Schneider Electric a. s.
Cizovska 447- 397 01 Pisek – Czech Republic*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Ui: 690V;Uimp: 8kV;Ith: 12A;AC-15: Ue/Ie: 220-240V/6A,
380-415V/4A, 500V/2A, 690V/1A;IP20

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

VZ7, VZ20;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020;IEC 60947-5-1:2024

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2025CQC-122935

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Aug.14,2025

Signature:

谢肇煦

Xie ZhaoXu

