

# Certificate of Compliance

**Certificate:** 2465317

**Master Contract:** 225619

**Project:** 2504430

**Date Issued:** March 19, 2012

**Issued to:** Telemecanique/Schneider Electric

**Industries SAS.  
BP 660  
Zone Industrielle No. 3  
L'Isle d'Espagnac, 16340  
France  
Attention: Mr. Jean-Pierre Laidet**

*The products listed below are eligible to bear the CSA Mark shown*



*J.-C. Chow*

**Issued by:** J.-C. Chow

## **PRODUCTS**

**CLASS 3211 03** - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

- Push-buttons, 22 mm line, Cat. No. XB7-NA, -NH or -NL, and Selector switches, Cat. No. XB7-ND or -NG, rated D300, R300. Suitable for enclosure Type 12.
- Illuminated push-buttons, 22 mm line, Cat. No. XB7-NW or -NJ, direct supply (incandescent or neon), rated 250Vac max, 50/60Hz, 1.2W max, or integral LED, rated 24Vac/dc-25mA, 120Vac-15mA, or 230Vac-27mA, 50/60Hz. Suitable for enclosure Type 12.
- Emergency Stop Push-buttons, 22 mm line, Cat. No. XB7-NS or -NT, rated C300, R300. Suitable for enclosure Type 3 or 12.

### Notes:

1. Cat. No. is followed by suffixes designating supply voltage, contacts, markings and colour options.
2. These open type devices are certified for use in other Certified equipment where the suitability of the combination is determined by CSA International.

## **APPLICABLE REQUIREMENTS**

CSA-C22.2 No.14-10 - Industrial Control Equipment



CSA INTERNATIONAL

**Certificate:** 2465317

**Master Contract:** 225619

**Project:** 2504430

**Date Issued:** March 19, 2012

---

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures