

# **Certificate of Compliance**

**Certificate:** 2661591 (LR 29971) **Master Contract:** 153555

**Project:** 70027705 **Date Issued:** April 13, 2015

Issued to: Schneider Electric USA, Inc.

Square D

3700 6th St SW

Cedar Rapids, IA 52404

**USA** 

**Attention: Manuel Salinas** 

## The products listed below are eligible to bear the CSA Mark shown



R. Tateishi

Issued by: R. Tateishi, P. Eng.

#### **PRODUCTS**

CLASS 1432 02 - CIRCUIT BREAKERS - Arc Fault Circuit Interrupters

Combined circuit breaker and arc fault circuit interrupter, Types QO and QOB, Series 1, 2-pole, 15 and 20A, 120/240V ac.

#### Notes:

- 1. These circuit breakers provide both series and parallel arc fault protection.
- 2. The Cat. Nos. QO(B)215CAFI and QO(B)220CAFI may be marked with an interrupting rating of 10,000 rms symmetrical amperes, 120/240V ac.
- 3. The Cat. Nos QO(B)215VHCAFI and QO(B)220VHCAFI may be marked with an interrupting rating of 22,000 rms symmetrical amperes, 120/240V ac.

#### **APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures

TIL No. M-02A - Interim Requirements for Arc-Fault Circuit Interrupters

DQD 507 Rev. 2012-05-22 Page: 1



## Supplement to Certificate of Compliance

Certificate: 2661591 Master Contract: 153555

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

### **Product Certification History**

Project	Date	Description
70027705 2661591	Apr 13, 2015 Nov 28, 2013	Addition of an alternate stationary contact.  Original Certification.

DQD 507 Rev. 2012-05-22 Page: 1