



Certificate of Compliance

Certificate: 80024451 **Master Contract:** 254977
Project: 80024451 **Date Issued:** 2020-01-16
Issued to: Telemecanique/Schneider Electric Industries SAS
BP 660
Zone Industrielle No. 3
L'Isle d'Espagnac, 16340
France

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Hannah Deng*
Hannah Deng

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Relay Socket, models RXZE14P.

ELECTRICAL RATINGS:

Model Name	Voltage	Current	Number of Pins
RXZE14P	300/250 V ac	8/6 A	14
RXZE14P (2 Pole)	300/250 V ac	12 A	8

Note:

1. This device shall be mounted within a suitable ultimate enclosure and with proper spacings being maintained.
2. This device is intended for factory wiring only (terminations not suitable for field wiring), and the suitability of the connection (including spacings between factory connections) shall be determined.
3. These devices have not been evaluated for making and breaking a load.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 14-18 - Industrial control equipment



Supplement to Certificate of Compliance

Certificate: 80024451

Master Contract: 254977

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80024451	2020-01-16	Multiple Listing for Telemecanique/Schneider Electric Industries SAS, Listee ID 254977, Relay Socket, model RXZE14P.

Original Report	Submittor's Model	Listee's Model
80024449	SKC14-ST	RXZE14P