

Certificate of Compliance

Certificate: 80024450 Master Contract: 254977

Project: 80024450 **Date Issued:** 2020-01-16

Issued to: Telemecanique/Schneider Electric Industries SAS

BP 660

Zone Industrielle No. 3 L'Isle d'Espagnac, 16340

France

The products listed below are eligible to bear the CSA Mark shown



Issued by: Hannah Deng Hannah Deng

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Relay Socket, models RGZE05P, RGZE08P, RSZE05P and RSZE08P.

ELECTRICAL RATINGS:

Model Name	Voltage	Current	Contact ratings
RGZE05P	300/250 V ac	16/10 A	1 form C
RGZE08P	300/250 V ac	10/5 A	2 form C
RSZE05P	300/250 V ac	12 A	1 form C
RSZE08P	300/250 V ac	10 A	2 form C

Note:

- 1. This device shall be mounted within a suitable ultimate enclosure and with proper spacings being maintained.
- 2. This device is intended for factory wiring only (terminations not suitable for field wiring), and the suitability of the connection (including spacings between factory connections) shall be determined.
- 3. These devices have not been evaluated for making and breaking a load.



 Certificate:
 80024450
 Master Contract:
 254977

 Project:
 80024450
 Date Issued:
 2020-01-16

APPLICABLE REQUIREMENTS

CSA C22.2 No. 14-18 - Industrial control equipment



Supplement to Certificate of Compliance

Certificate: 80024450 Master Contract: 254977

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description					
80024450	2020-01-16		Multiple Listing for Telemecanique/Schneider Electric Industries SAS, Listee ID 254977, Relay Socket, models RGZE05P, RGZE08P, RSZE05P and RSZE08P.				
		Original Report	Submittor's Models	Listee's Models			
			SRC05-ST	RSZE05P			
			SRC08-ST	RSZE08P			
			SRU05-ST	RGZE05P			
		80024448	SRU08-ST	RGZE08P			