

IEC

IECEE



Ref. Certif. No.

CN71957

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Electronic Overload Relays

Name and address of the applicant

Schneider Electric Industries SAS
35 Rue Joseph Monier, 92500 Rueil-Malmaison France

Name and address of the manufacturer

Schneider Electric (China) Co., Ltd.
Block A, No.6 East Wangjing Road, Chaoyang District, Beijing,
P.R.China

Name and address of the factory

TAIAN Technology (Wuxi) Co., Ltd.
Block 65-C, Wuxi National High-Technology Industry Development
Zone, Wuxi, Jiangsu Province, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Ui: 1000V;Uimp: 6kV;Ue: 690V;Ie: 0.1-0.5A, 0.4-2A, 1.6-8A,
6.4-32A;Tripping class: 5,10,20,30;Pole: 3P;IP code: IP20 (only
applicable to terminals);Auxiliary contacts (body):Ith: 5A;AC-15:
Ue/Ie: 24V/4.17A, 48V/4.17A, 110V/3.64A, 220V/2.73A,
380V/1.58A, 600V/1A; DC-13: Ue/Ie: 24V/4.17A, 48V/2.08A,
110V/0.45A, 125V/0.22A, 220V/0.20A;1NO1NC

Trademark (if any)

SCHNEIDER ELECTRIC

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

LR9D01, LR9D02, LR9D08, LR9D32;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-1:2020;IEC 60947-4-1:2023

As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2025CQC-121263

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jul.09,2025

Signature:

谢肇煦

Xie ZhaoXu

