



# Certificate of Compliance

**Certificate:** 1793277 (LR 32390)

**Master Contract:** 153555

**Project:** 2525131

**Date Issued:** May 15, 2012

**Issued to:** Schneider Electric USA, Inc.

Square D  
3700 6th St SW  
Cedar Rapids, IA 52404  
USA  
Attention: Bill Rezac

*The products listed below are eligible to bear the CSA Mark shown*



*R. Tateishi*

**Issued by:** R. Tateishi, P. Eng.

## **PRODUCTS**

**CLASS 4652 04** - SWITCHES - Miscellaneous

Instantaneous trip circuit breakers, Powerpact HJ, HL and HR, 3-pole, 150A max, 600V ac max.

Instantaneous trip circuit breakers, Powerpact JJ, JL and JR, 3-pole, 250A max, 600V ac max.

## **APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures