



Ref. Certif. No.

**DK-154889-UL**

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

EMERGENCY STOP DEVICE (PUSH BUTTON SWITCH): Harmony range XB4 metal and XB5 plastic.

Name and address of the applicant

Schneider Electric Industries SAS  
35 RUE JOSEPH MONIER RUEIL MALMAISON 92500  
France

Name and address of the manufacturer

Schneider Electric Industries  
Boulevard Salvador Allende  
ZI N°3 – BP 660  
16 340 L'Isle D'espagnac, France

Name and address of the factory

Schneider Electric / DBA Telemecanique  
Zone Industrielle  
BP660 L'Isle D'Espagnac 16340  
France

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

☒ Additional Information on page 2

Utilization Category:

AC15 – DC-13  
A600 – Q600  
A300 – Q300 – P300  
B300 – R300

Resistive

☒ Additional Information on page 2-3

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF Stage 3

Model / Type Ref.

Series XB4, XB5, ZB4 or ZB5 series followed by BS83, BS84, BS86, BS93, BS94, BS96, BT84, BX84, AS83, AS84, AS86, AS93, AS94, AS96, AT84, AT86, AX84 followed by additional suffixes, and fitted with : ZB..Z009 + ZBE, ZEN or ZB2 followed by additional digits XALK84, XALK178 followed additional suffixes.

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-5-5:1997, IEC 60947-5-5:1997/AMD1:2005,  
IEC 60947-5-5:1997/AMD2:2016, IEC 60947-1:2007,  
IEC 60947-1:2007/AMD1:2010, IEC 60947-1:2007/AMD2:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

4790905385.2 issued on 2024-06-06

This CB Test Certificate is issued by the National Certification Body



- ☐ UL Solutions (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- ☒ UL Solutions (Denmark), Borupvang 5A DK-2750 Ballerup, DENMARK
- ☐ UL Solutions (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- ☐ UL Solutions (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2024-07-19

Signature:

Thomas Wilson



Ref. Certif. No.

**DK-154889-UL**

**Factory(ies):**

SCHNEIDER ELECTRIC a.s.  
CIZOVSKA 447 PISEK 397 01  
Czech Republic

PT. SCHNEIDER ELECTRIC MANUFACTURING BATAM  
Batamindo Industrial Park  
Jl. Beringin Lot 1, 4 208  
Batam 29433 Batam, Riau, 29433  
Indonesia

**Additional Ratings:**

Supply Rating:

24 V – 0.1 A

Rated Operational Voltage Ue:

120 Vac, 240 Vac,

125 Vdc, 250 Vdc

600 Vac,

600 Vdc

Rated Impulse Voltage:

250 V

500 V

600 V

Rated Impulse Withstand Voltage: Uimp:

4 kV

6 kV

Conventional free air thermal current Ith:

6 A

10 A

Conventional enclosed thermal current Ithe:

6 A

10 A

Rated Operational Current Ie:

6 Aac, 3 Aac,

1,2 Aac,

0.55 Adc,

0,27 Adc, 0,1 Adc

0,22 Adc

1,1 Adc

1,5 Aac

**Additional information (if necessary)**



- ☐ UL Solutions (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- ☒ UL Solutions (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- ☐ UL Solutions (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- ☐ UL Solutions (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2024-07-19

Signature:

Thomas Wilson



Ref. Certif. No.

**DK-154889-UL**

**Additional Ratings (CONT'D):**

Rated frequency:

50 – 60 Hz

Rated conditional short circuit current:

1000 A

Protection degree:

66, 67 (front)

20 (back)

Pollution Degree:

3

See CB Test Report for complete set of ratings vs. Models covered

**Additional information (if necessary)**



- ☐ UL Solutions (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- ☒ UL Solutions (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- ☐ UL Solutions (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- ☐ UL Solutions (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2024-07-19

Signature:

Thomas Wilson