



## CERTIFICATE

No. Z10 128850 0002 Rev. 00

**Holder of Certificate:** Schneider Electric Industries SE

33 rue André Blanchet 27120 Pacy-sur-Eure

**FRANCE** 

**Certification Mark:** 



Safety components **Product:** 

**ATV320** Model(s):

SIL 3, SILCL 3, Cat3, PLe **Parameters:** 

Power supply: 200-600V

Working temperature (functional): -10°C to +60°C

Working temperature (STO/SS1/SLS/SMS/GDL): -10°C to +60°C

The report listed below and the user documentation are mandatory part of this certificate. The certified components are listed in report

1\_/hc

S2104239T in the current valid version.

2006/42/EC **Tested** 

IEC 61508-1:2010 according to:

IEC 61508-2:2010

IEC 61508-3:2010 IEC 62061:2021 ISO 13849-1:2023 UL 61800-5-2:2022

IEC 61800-5-2:2016

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: S2104239T Valid until: 2030-02-18

Date. 2025-02-25

(Thomas Kreten)