



# Certificate of Compliance

<b>Certificate:</b>	70128984	<b>Master Contract:</b>	179014
<b>Project:</b>	80203918	<b>Date Issued:</b>	2024-06-20
<b>Issued to:</b>	<b>Schneider Electric Industries S A S</b> <b>Power Business Unit / FLV</b> <b>Electropole/EYBENS</b> <b>31 rue Pierre Mendes France</b> <b>Grenoble Cedex, Isere 38050</b> <b>France</b>  <b>Attention:</b> Juan Carlos Mico		

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** *Franklin ten Haaf*  
Franklin ten Haaf

**PRODUCTS**

Class 1432 01 CIRCUIT BREAKERS - Moulded Case Type

**Moulded case circuit breakers, Types C60BP and C60BPR**

Model(s)	Current (A max)	Voltage (V ac) Max	Voltage (VDC max)	Current (A max)	Voltage (V ac) Max
1-pole	0.5 to 63	240	60	0.5 to 35	277

Notes:

1. These circuit breakers are suitable for use with copper conductors only.
2. These circuit breakers may be marked with interrupting ratings in maximum RMS Symmetrical Amperes as follows:

Voltages		Ratings	
		0.5A up to 35A	40 up to 63A
120V 1P	AC	14 kA	10 kA
240V 1P	AC	14 kA	10 kA



**Certificate:** 70128984

**Master Contract:** 179014

**Project:** 80203918

**Date Issued:** 2024-06-20

277V 1P	AC	10 kA	-
60V 1P	DC	10 kA	10 kA

Moulded case circuit breakers, Types C60BP and C60BPR

Model(s)	Current (A max)	Voltage (VDC max)	Current (A max)	Voltage (V ac) Max	Current (A max)	Voltage (V ac) Max
2-pole	0.5 to 25A	125	0.5 to 35	480/277	0.5 to 63	240

Notes:

1. These circuit breakers are suitable for use with copper conductors only.
2. These circuit breakers may be marked with interrupting ratings in maximum RMS Symmetrical Amperes as follows:

Voltages		Ratings	
		0.5A up to 35A	40 up to 63A
240V 2P	AC	14 kA	10 kA
480Y/277V 2P	AC	10 kA	-
125V 2P	DC	10 kA*	-

\*Ratings 0.5 up to 25A

Moulded case circuit breakers, Types C60BP and C60BPR

Model(s)	Current (A max)	Voltage (V ac) Max	Current (A max)	Voltage (V ac) Max
3-pole	0.5 to 35	480/277	0.5 to 63	240

Notes:

1. These circuit breakers are suitable for use with copper conductors only.
2. These circuit breakers may be marked with interrupting ratings in maximum RMS Symmetrical Amperes as follows:

Voltages		Ratings	
		0.5A up to 35A	40 up to 63A
240V 3P	AC	14 kA	10 kA
480Y/277V 3P	AC	10 kA	-

**APPLICABLE REQUIREMENTS**

CSA C22.2 No. 5-16 Upd.1 (Fourth Edition, April 2019) - Molded-case circuit breakers, molded-case switches, and circuit-breaker enclosures



**Certificate:** 70128984


**Master Contract:** 179014

**Project:** 80203918

**Date Issued:** 2024-06-20

Notes:

Products certified under Class(es) C143201 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). [www.scc.ca](http://www.scc.ca)





## *Supplement to Certificate of Compliance*

**Certificate:** 70128984

**Master Contract:** 179014

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
80203918	2024-06-20	Update to Report 70128984 to change the plastic name from Eurostar Engineering Plastics to Ascend. Main Standard shall be updated according to notice Circuitbreakers06_switches22 & Circuitbreakers07_switches23.
70128984	2017-04-26	Original Certification of moulded case circuit breakers, Types C60BP and C60BPR.