



global-mark®

Certificate of Conformity

Global-Mark Pty. Ltd., certify the electrical equipment described hereunder complies with standards listed herein and notifies the certificate holder to affix the authorised Approval Mark on the product of the same type and the Regulatory Compliance Mark (RCM) mark provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled. In placing the Approval and RCM mark on the product, the Responsible Supplier makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. – This Certificate meets the requirements of a Recognised External Certification Scheme (EESS- RECS) and a Recognised External Approval Scheme (NSW-REAS).

CERTIFICATION AND CERTIFICATE HOLDER DETAILS

Company Name	Schneider Electric (Australia) Pty Ltd	Other Name	CLIPSAL
Address	33-37 Port Wakefield Road Gepps Cross SA 5094 Australia		
Client ID	102093	Global-Mark File Number:	102093-320
Certificate Number & Approval Mark	GMA-510949-EA	Revision Number	00
Certification Standard(s)	AS/NZS IEC 60947.2:2015 Low-voltage switchgear and controlgear Part 2: Circuit-breakers		
Type of Certification	Electrical Safety Product	<i>Scheme</i>	Global-Mark Electrical Product Safety Certification Scheme

System 1 Approval

CERTIFICATE DATES

Certificate Issue Date	27/10/2021
Certificate Last Update Date	
Certification Expiry Date	27/10/2026

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER

Certificate of Conformity

CERTIFIED ELECTRICAL EQUIPMENT				
Declared Article	Product Description	Trade Name	Model Number	Rating
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22102	240/415Vac 50/60Hz 1P C 2A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22103	240/415Vac 50/60Hz 1P C 3A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22104	240/415Vac 50/60Hz 1P C 4A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22106	240/415Vac 50/60Hz 1P C 6A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22108	240/415Vac 50/60Hz 1P C 8A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22110	240/415Vac 50/60Hz 1P C 10A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22113	240/415Vac 50/60Hz 1P C 13A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22116	240/415Vac 50/60Hz 1P C 16A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22120	240/415Vac 50/60Hz 1P C 20A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22125	240/415Vac 50/60Hz 1P C 25A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22132	240/415Vac 50/60Hz 1P C 32A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22150	240/415Vac 50/60Hz 1P C 50A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22163	240/415Vac 50/60Hz 1P C 63A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22201	240/415Vac 50/60Hz 2P C 1A 20kA@240Vac, 10kA@415Vac

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager





global-mark®

Certificate of Conformity

Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22202	240/415Vac 50/60Hz 2P C 2A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22204	240/415Vac 50/60Hz 2P C 4A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22206	240/415Vac 50/60Hz 2P C 6A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22210	240/415Vac 50/60Hz 2P C 10A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22216	240/415Vac 50/60Hz 2P C 16A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22220	240/415Vac 50/60Hz 2P C 20A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22225	240/415Vac 50/60Hz 2P C 25A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22232	240/415Vac 50/60Hz 2P C 32A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22240	240/415Vac 50/60Hz 2P C 40A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22250	240/415Vac 50/60Hz 2P C 50A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22263	240/415Vac 50/60Hz 2P C 63A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22302	240/415Vac 50/60Hz 3P C 2A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22306	240/415Vac 50/60Hz 3P C 6A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22310	240/415Vac 50/60Hz 3P C 10A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22316	240/415Vac 50/60Hz 3P C 16A 20kA@240Vac,10kA@415Vac

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER



global-mark®

Certificate of Conformity

Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22320	240/415Vac 50/60Hz 3P C 20A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22325	240/415Vac 50/60Hz 3P C 25A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22332	240/415Vac 50/60Hz 3P C 32A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22340	240/415Vac 50/60Hz 3P C 40A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22350	240/415Vac 50/60Hz 3P C 50A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F22363	240/415Vac 50/60Hz 3P C 63A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23101	240/415Vac 50/60Hz 1P D 1A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23102	240/415Vac 50/60Hz 1P D 2A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23103	240/415Vac 50/60Hz 1P D 3A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23104	240/415Vac 50/60Hz 1P D 4A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23106	240/415Vac 50/60Hz 1P D 6A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23108	240/415Vac 50/60Hz 1P D 8A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23110	240/415Vac 50/60Hz 1P D 10A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23113	240/415Vac 50/60Hz 1P D 13A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23116	240/415Vac 50/60Hz 1P D 16A 10kA@240Vac, 3kA@415Vac

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER



global-mark®

Certificate of Conformity

Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23120	240/415Vac 50/60Hz 1P D 20A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23125	240/415Vac 50/60Hz 1P D 25A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23132	240/415Vac 50/60Hz 1P D 32A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23140	240/415Vac 50/60Hz 1P D 40A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23201	240/415Vac 50/60Hz 2P D 1A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23202	240/415Vac 50/60Hz 2P D 2A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23203	240/415Vac 50/60Hz 2P D 3A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23204	240/415Vac 50/60Hz 2P D 4A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23205	240/415Vac 50/60Hz 2P D 5A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23206	240/415Vac 50/60Hz 2P D 6A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23210	240/415Vac 50/60Hz 2P D 10A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23216	240/415Vac 50/60Hz 2P D 16A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23220	240/415Vac 50/60Hz 2P D 20A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23302	240/415Vac 50/60Hz 3P D 2A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23306	240/415Vac 50/60Hz 3P D 6A 20kA@240Vac, 10kA@415Vac

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER



global-mark®

Certificate of Conformity

Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23310	240/415Vac 50/60Hz 3P D 10A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23316	240/415Vac 50/60Hz 3P D 16A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23320	240/415Vac 50/60Hz 3P D 20A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23325	240/415Vac 50/60Hz 3P D 25A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23332	240/415Vac 50/60Hz 3P D 32A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60SP MCB	Schneider Electric	M9F23340	240/415Vac 50/60Hz 3P D 40A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42101	240/415Vac 50/60Hz 1P C 1A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42102	240/415Vac 50/60Hz 1P C 2A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42103	240/415Vac 50/60Hz 1P C 3A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42104	240/415Vac 50/60Hz 1P C 4A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42105	240/415Vac 50/60Hz 1P C 5A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42106	240/415Vac 50/60Hz 1P C 6A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42108	240/415Vac 50/60Hz 1P C 8A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42110	240/415Vac 50/60Hz 1P C 10A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42115	240/415Vac 50/60Hz 1P C 15A 10kA@240Vac, 3kA@415Vac

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER



global-mark®

Certificate of Conformity

Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42120	240/415Vac 50/60Hz 1P C 20A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42125	240/415Vac 50/60Hz 1P C 25A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42130	240/415Vac 50/60Hz 1P C 30A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42135	240/415Vac 50/60Hz 1P C 35A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42170	240/415Vac 50/60Hz 1P C 0,5A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42201	240/415Vac 50/60Hz 2P C 1A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42202	240/415Vac 50/60Hz 2P C 2A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42203	240/415Vac 50/60Hz 2P C 3A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42204	240/415Vac 50/60Hz 2P C 4A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42205	240/415Vac 50/60Hz 2P C 5A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42206	240/415Vac 50/60Hz 2P C 6A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42208	240/415Vac 50/60Hz 2P C 8A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42210	240/415Vac 50/60Hz 2P C 10A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42215	240/415Vac 50/60Hz 2P C 15A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42220	240/415Vac 50/60Hz 2P C 20A 20kA@240Vac, 10kA@415Vac

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER



global-mark®

Certificate of Conformity

Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42225	240/415Vac 50/60Hz 2P C 25A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42230	240/415Vac 50/60Hz 2P C 30A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42235	240/415Vac 50/60Hz 2P C 35A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42301	240/415Vac 50/60Hz 3P C 1A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42302	240/415Vac 50/60Hz 3P C 2A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42303	240/415Vac 50/60Hz 3P C 3A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42304	240/415Vac 50/60Hz 3P C 4A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42305	240/415Vac 50/60Hz 3P C 5A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42306	240/415Vac 50/60Hz 3P C 6A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42308	240/415Vac 50/60Hz 3P C 8A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42310	240/415Vac 50/60Hz 3P C 10A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42315	240/415Vac 50/60Hz 3P C 15A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42320	240/415Vac 50/60Hz 3P C 20A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42325	240/415Vac 50/60Hz 3P C 25A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42330	240/415Vac 50/60Hz 3P C 30A 20kA@240Vac,10kA@415Vac

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER

Certificate of Conformity

Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42335	240/415Vac 50/60Hz 3P C 35A 20kA@240Vac, 10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43101	240/415Vac 50/60Hz 1P D 1A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43102	240/415Vac 50/60Hz 1P D 2A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43103	240/415Vac 50/60Hz 1P D 3A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43104	240/415Vac 50/60Hz 1P D 4A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43105	240/415Vac 50/60Hz 1P D 5A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43106	240/415Vac 50/60Hz 1P D 6A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43108	240/415Vac 50/60Hz 1P D 8A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43110	240/415Vac 50/60Hz 1P D 10A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43115	240/415Vac 50/60Hz 1P D 15A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43120	240/415Vac 50/60Hz 1P D 20A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43125	240/415Vac 50/60Hz 1P D 25A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43130	240/415Vac 50/60Hz 1P D 30A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43135	240/415Vac 50/60Hz 1P D 35A 10kA@240Vac, 3kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43170	240/415Vac 50/60Hz 1P D 0,5A 10kA@240Vac, 3kA@415Vac

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager





global-mark®

Certificate of Conformity

Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43201	240/415Vac 50/60Hz 2P D 1A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43202	240/415Vac 50/60Hz 2P D 2A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43203	240/415Vac 50/60Hz 2P D 3A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43204	240/415Vac 50/60Hz 2P D 4A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43205	240/415Vac 50/60Hz 2P D 5A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43206	240/415Vac 50/60Hz 2P D 6A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43208	240/415Vac 50/60Hz 2P D 8A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43210	240/415Vac 50/60Hz 2P D 10A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43215	240/415Vac 50/60Hz 2P D 15A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43220	240/415Vac 50/60Hz 2P D 20A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43225	240/415Vac 50/60Hz 2P D 25A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43230	240/415Vac 50/60Hz 2P D 30A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43235	240/415Vac 50/60Hz 2P D 35A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43301	240/415Vac 50/60Hz 3P D 1A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43302	240/415Vac 50/60Hz 3P D 2A 20kA@240Vac,10kA@415Vac

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER



global-mark®

Certificate of Conformity

Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43303	240/415Vac 50/60Hz 3P D 3A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43304	240/415Vac 50/60Hz 3P D 4A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43305	240/415Vac 50/60Hz 3P D 5A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43306	240/415Vac 50/60Hz 3P D 6A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43308	240/415Vac 50/60Hz 3P D 8A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43310	240/415Vac 50/60Hz 3P D 10A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43315	240/415Vac 50/60Hz 3P D 15A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43320	240/415Vac 50/60Hz 3P D 20A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43325	240/415Vac 50/60Hz 3P D 25A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43330	240/415Vac 50/60Hz 3P D 30A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F43335	240/415Vac 50/60Hz 3P D 35A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42240	240/415Vac 50/60Hz 2P C 40A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42250	240/415Vac 50/60Hz 2P C 50A 20kA@240Vac,10kA@415Vac
Miniature overcurrent circuitbreaker	Multi9 C60BP MCB	Schneider Electric	M9F42263	240/415Vac 50/60Hz 2P C 63A 20kA@240Vac,10kA@415Vac

RELEVANT TRADEMARK (S)

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager





global-mark®

Certificate of Conformity

COMMENTS OR CONDITIONS ON THE CERTIFICATION
Nil

End of document



This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Conformity remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to www.jas-anz.org/register for verification.



Certification Manager

Global-Mark Pty Ltd, Copyright 2012 - 407, 32 Delhi Road, North Ryde NSW 2113, Australia



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER