



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010307640649

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

NAME AND LOCATION OF THE FACTORY

Merlin Gerin Alès
16 Boulevard Charles PEGUY 30319 Ales Cedex

PRODUCT NAME,MODEL AND SPECIFICATION

Moulded Case Circuit-breaker
C60SP, C60BP, C60BPR ; See the appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.2-2020

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jun.11,2024

Valid until: Jun.10,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010307640649

Appendix: Page 1 of 2

C60SP, C60BP, C60BPR

Uimp: 6kV;

Ui: 500V;

Uc: AC240V/415V (1P) ; AC240V, 415V, 440V (2P, 3P, 4P) ;

In: See table 1

Table 1 Rated current

极数 Nr. of pole s	类型 Type	额定电流 Rated current (A)																				
		0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
1P	Z	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
	B	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
	C	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
	D & K	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40			
2P	B	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
	C	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
	D & K	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40			
3P	B	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
	C	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
	D & K	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40			

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010307640649

Appendix : Page 2 of 2

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

	K	5																				
4P	B	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
	C	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
	D & K	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40			

Over current release type: Thermal Magnetic type;

Ics: 0.75Icu

Icu : See table 1

Table 2 Rated ultimate short-circuit capacity Icu

Ue	Icu			
	1P	2P	3P	4P
240V AC	10kA	20kA	20kA	20kA
415V AC	3kA	10kA	10kA	10kA
440V AC	/	6kA	6kA	6kA

Selectivity
Poles: 1P, 2P, 3P,
50/60Hz

Category: A;
4P;

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.