



# 中国国家强制性产品认证证书

证书编号：2018010307073663

委托人名称、地址

Schneider Electric Industries SAS  
31 Rue Pierre Mendès France, Eybens, 38050 GRENOBLE Cedex 9 - France

生产者（制造商）名称、地址

Schneider Electric Industries SAS  
31 Rue Pierre Mendès France, Eybens, 38050 GRENOBLE Cedex 9 - France

生产企业名称、地址

Merlin Gerin Alès  
1 rue Maurice Ravel, zone industrielle de Croupillac F-30319 ALES Cedex.  
France

产品名称和系列、规格、型号

塑料外壳式断路器  
C60SP, C60BP, C60BPR; 详情见附件

产品标准和技术要求

GB/T14048.2-2008

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，  
特发此证。

发证日期：2018年05月18日 有效期至：2023年05月18日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任：



## 中国质量认证中心





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

**CERTIFICATE NO.:** 2018010307073663

## **NAME AND ADDRESS OF THE APPLICANT**

Schneider Electric Industries SAS  
31 Rue Pierre Mendès France, Eybens, 38050 GRENOBLE Cedex 9 - France

## **NAME AND ADDRESS OF THE MANUFACTURER**

Schneider Electric Industries SAS  
31 Rue Pierre Mendès France, Eybens, 38050 GRENOBLE Cedex 9 - France

## **NAME AND ADDRESS OF THE FACTORY**

Merlin Gerin Alès  
1 rue Maurice Ravel, zone industrielle de Croupillac F-30319 ALES Cedex. France

## **PRODUCT NAME, MODEL AND SPECIFICATION**

Moulded Case Circuit-breaker  
C60SP, C60BP, C60BPR; See the appendix

## **THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T14048.2-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

**Valid from:** May.18,2018

**Valid until:** May.18,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao



**CHINA QUALITY CERTIFICATION CENTRE**





# 中国国家强制性产品认证证书

附 录

第 1 页 共 2 页

证书编号: 2018010307073663

纸 号: 1948276

C60SP, C60BP, C60BPR

额定冲击耐受电压(Uimp): 6kV;

额定绝缘电压(Ui): 500V;

额定工作电压(Ue): AC240V/415V (1P); AC240V, 415V, 440V (2P, 3P, 4P);

额定电流(In): 见表 1

表 1

极数	类型	额定电流(A)																				
		0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
1P	Z	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
	B	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
	C	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
	D & K	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40			
2P	B	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
	C	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
	D & K	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40			
3P	B	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
	C	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
	D & K	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40			
4P	B	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
	C	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40	45	50	63
	D & K	0.5	1	2	3	4	5	6	8	10	13	15	16	20	25	30	32	35	40			

过电流脱扣器类型: 热磁式;

额定运行短路分断能力(Ics): 0.75Icu

额定极限短路分断能力(Icu):

Ue

1P 2P 3P 4P

240V AC 10kA 20kA 20kA 20kA

注: 此附录与证书同时使用时有效。



主 任:



## 中国质量认证中心





# 中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2018010307073663

纸 号: 1948276

415V AC 3kA 10kA 10kA 10kA

440V AC / 6kA 6kA 6kA

使用类别: A;

极数: 1P, 2P, 3P, 4P;

适用频率: 50/60Hz

型号解释:

<u>C60BP</u>	<u>I</u>	<u>D</u>	<u>32</u>
I	II	III	IV

I: 产品型号:

C60BP (端子类型: 隧道式接线端子)

C60BPR (端子类型: 环形接线端子)

C60SP (端子类型: 柱形接线端子)

II: 极数: 1, 2, 3, 4P

III: 脱扣类型:

Z:  $I_i = 3I_n \pm 20\%$ ; B:  $I_i = 4I_n \pm 20\%$ ; C:  $I_i = 8.5I_n \pm 20\%$ ; D / K:  $I_i = 12I_n \pm 20\%$  (D=K)

IV: Rated current

0.5, 1, 2, 3, 4, 5, 6, 8, 10, 13, 15, 16, 20, 25, 30, 32, 35, 40, 45, 50, 63A

注: 此附录与证书同时使用时有效。



主 任:



## 中国质量认证中心