

CERTIFICATE OF COMPLIANCE

Certificate Number E63335
Report Reference E63335-20110610
Issue Date 2020-JUNE-02

Issued to: SCHNEIDER ELECTRIC INDUSTRIES SAS
ELECTROPOLE/EYBENS, POWER / LV
31 RUE PIERRE MENDES FRANCE
38050 GRENOBLE CEDEX 9 FRANCE

This certificate confirms that representative samples of CIRCUIT BREAKERS, MOLDED CASE AND CIRCUIT-BREAKER ENCLOSURES

Refer to Addendum Page for Models/Product.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 489 Standard for Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures.

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E63335
Report Reference E63335-20110610
Issue Date 2020-JUNE-02

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models/Product

Molded case circuit breakers type POWERPACT L with prefix LD, LG, LJ, LL, LR or NLD, NLG, NLJ, NLL, NLR rated 250A, 400 A and 600 A, 600 V ac, 3 and 4 poles. Type TeSys GV6PB, followed by 400 or 600, followed by N or S, followed by additional suffixes 3P.

Molded case circuit breakers POWERPACT L with prefix LG, LJ or NLG, NLJ rated 250A, 300A, 350A, 400A, 500A and 600A, 600 V ac, 2 and 3 poles.

Molded case circuit breakers POWERPACT L for UPS application with suffix LG and LL rated 600A maximum frame rating for 3P 1200A maximum frame rating for 2P and voltage rating of 500 Vdc.

- Square D – Type LD, LG, LJ, LL, LR
- Schneider Electric – Type NLD, NLG, NLJ, NLL, NLR



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

