

Declaration of Conformity

Issued by Manufacturer
Hoffman Enclosures, Inc.
2100 Hoffman Way, Anoka, Minnesota 55303-1745, U.S.A.
declare at our sole responsibility, that these devices are designed and constructed according to
the fundamental safety and health requirements.

Enclosure Models: HSDS##SS & HSDH##SS

Equipment Description: Hoffman Industrial Control Enclosure HYSHED Platform
Stainless Steel

Environmental Rating : NEMA / UL / cUL Type 4, 4X, 12
IP 66, IP69K

Enclosure Certification: UL508A per E61997

Silicone (blue) gasket conforms to FDA GUIDELINE 21 CFR 177.2600

File E61997 Vol. 1 Sec. 27 Page 1 Issued: 2017-12-08
and Report

DESCRIPTION

PRODUCT COVERED:

USL, CNL - Enclosures for Industrial Control Panels, Types 3, 3R, 4, 4X and 12 -
Models HSDS##SS and HSDH##SS.

Applicable Standards: UL508A Industrial Control Panel Enclosure
UL 50 Enclosures for Electrical Equipment, Non-
Environmental Considerations
UL 50E Enclosures for Electrical Equipment, Environmental
Considerations
cUL to CSA C22.2 No. 14, 94.1 and 94.2
NEMA250 Enclosures for Electrical Equipment (1000 Volts Maximum)

Authorized by:



4/6/2023

Tom Hurney

Date

Technology Mgr., Product Compliance and Approvals

DOC: CERT-00237 D

Subject to Change Without Notice

CERTIFICATE OF COMPLIANCE

Certificate Number 20190815-E61997
Report Reference E61997-20171208
Issue Date 2019-AUGUST-15

Issued to: Hoffman Enclosures Inc
2100 Hoffman Way
Anoka MN 55303-1738

This certificate confirms that
representative samples of

INDUSTRIAL CONTROL PANELS
Enclosures for Industrial Control Panels, Types 3, 3R, 4, 4X
and 12 – Models HSDS##SS and HSDH##SS.
Model number suffix “##” will designate the size of the
enclosure.
HSDS = HYSHED TM Screw Cover
HSDH = HYSHED TM Hinged Cover

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 508A Standard For Industrial Control Panels
CSA C22.2 No. 14-13 Industrial Control Equipment

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's
Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/about/certification>

