



# Certificate of Compliance

**Certificate:** 1191684 (LR 7551)

**Master Contract:** 153555

**Project:** 2709354

**Date Issued:** March 11, 2014

**Issued to:** Schneider Electric USA, Inc.

Square D  
3700 6th St SW  
Cedar Rapids, IA 52404  
USA  
Attention: Bill Rezac

*The products listed below are eligible to bear the CSA Mark shown*



*Ron Tateishi*

**Issued by:** Ron Tateishi

## **PRODUCTS**

**CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type**

Moulded case circuit breakers, Powerpact R, Cat No Prefixes RG, RJ, RK and RL, 2-, 3- and 4-pole, 600-3000A, 600V ac max.

### Notes:

These circuit breakers may also be brand labelled for Merlin Gerin, Federal Pioneer and Federal Pacific and bear the Cat No Prefixes NRG, NRJ, NRK and NRL; FRG, FRJ, FRK and FRL; PRG, PRJ, PRK and PRL, respectively.

## **APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures