



Ref. Certif. No.

HU-003256

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Family of Molded Case Circuit Breakers
Name and address of the applicant	Schneider Electric 3700 6th street SW Cedar Rapids IA 52404, USA
Name and address of the manufacturer	Schneider Electric 3700 6th street SW Cedar Rapids IA 52404, USA
Name and address of the factory	Schneider Electric 4800, Paris Rd Columbia 65202, USA
Ratings and principal characteristics	Rated op. voltage (Ue): AC220/240V, AC380/440V, AC500/525V; Rated current (In): 250A, 400A, 600A; Rated frequency: 50Hz; Rated insulation voltage (Ui): 800V Rated impulse withstand voltage (Uimp): 8kV
Trademark (if any)	SQUARE D
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	Powerpact LD, LG, LJ and LL series with electronic release
Additional information (if necessary may also be reported on page 2)	(See further details in Test Report)
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016
As shown in the Test Report Ref. No. which forms part of this Certificate	HU2052WS 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division  
H-1143 Budapest, Gizella út 51-57., Hungary  
Web: www.tuv.com

Date: 2020-12-23

Signature:

Gergely Bakos