



Certificate of Compliance

Certificate: 1534832 (LR 40970)

Master Contract: 153555

Project: 2554569

Date Issued: October 17, 2012

Issued to: Schneider Electric USA, Inc.

Square D
3700 6th St SW
Cedar Rapids, IA 52404
USA
Attention: Bill Rezac

The products listed below are eligible to bear the CSA Mark shown



R. Tateishi

Issued by: R. Tateishi, P. Eng.

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Molded case circuit breakers, Powerpact HD, HG, HJ, HL and HR, 2- and 3-pole, 150A max, 600V ac max, 250V dc max.

Molded case circuit breakers, Powerpact JD, JJ, JL and JR, 2- and 3-pole, 250A max, 600V ac max, 250V dc max.

Molded case circuit breakers, Powerpact JG, 2- and 3-pole, 250A max, 600V ac max, 500V dc max.

Molded case circuit breakers, Powerpact JD-W, JG-W, JJ-W, and JL-W, 3 pole, electronic trip, 250A max, 480Y/277V ac.

CLASS 1437 01 - CIRCUIT BREAKERS - Accessories

External neutral current transformers, Cat. Nos. LV429521, LV430563, LV432575, S429521, S430562, S430563, and S432575 for use with the submittor's Certified moulded case circuit breakers, Cat. No. Prefixes H, J, L and NSX.

APPLICABLE REQUIREMENTS



Certificate: 1534832 (LR 40970)

Master Contract: 153555

Project: 2554569

Date Issued: October 17, 2012

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures