



# Certificate of Compliance

**Certificate:** 1052568 (LR 92886-78)

**Master Contract:** 153555

**Project:** 70067731

**Date Issued:** 2016-03-21

**Issued to:** Schneider Electric USA, Inc.  
Square D  
3700 6th St SW  
Cedar Rapids, Iowa 52404  
USA  
**Attention:** Manuel Salinas

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** *Ronald Tateishi*  
Ronald Tateishi

## PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Circuit breakers, Types HOMT and CHOMT, Series 1, two 1-pole breakers in a common case, 15, 20, 25, 30, 40 and 50A, 120/240V ac max.

### Notes:

1. The mechanism is trip free of the handle which assumes a mid position between "ON" and "OFF" upon automatic tripping.
2. These circuit breakers are uncompensated and calibrated to 40°C requirements.
3. These circuit breakers are suitable for use with copper and aluminum conductors.
4. These circuit breakers are suitable for reversed line and load connections.
5. These circuit breakers may be marked with a high current interrupting rating of 10,000 rms symmetrical A at 120/240V ac.

## APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures



## *Supplement to Certificate of Compliance*

**Certificate:** 1052568 (LR 92886-78)

**Master Contract:** 153555

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
70067731	2016-03-21	Addition of alternate plastic material (BMC 605) for the handles.
2368780	2010-11-29	Addition of the Type CHOMT circuit breakers.
1052568	2000-02-16	Addition of 40 and 50A ratings.
LR 92886-93	1998-12-04	Change in the bimetal in the 25A breaker.
LR 92886-78	1998-03-02	Original Certification.