

CERTIFICATE OF COMPLIANCE

Certificate Number 20170605-E84967
Report Reference E84967-19920310
Issue Date 2017-JUNE-05

Issued to: SCHNEIDER ELECTRIC USA, INC.
1010 AIRPARK CENTER DR
NASHVILLE TN 37217

**This is to certify that
representative samples of**

CIRCUIT BREAKERS, MOLDED CASE AND CIRCUIT-
BREAKER ENCLOSURES

Molded case circuit breaker and remote controlled circuit-interrupter Types QO and QOB, Cat. Nos. QO-PL, QO-PLILC, and QOB-PL, QOB-PLILC, respectively, rated 15 through 30 A, 120/240 V ac, 1-pole; 15 through 60 A, 120/240 V ac, 2-pole; and QO-PL & QOB-PL, 15 through 30 A, 240 V ac, 3-pole.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 489, Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

