

Northbrook, Illinois • (847) 272-8800
Melville, New York • (631) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549 1400
Camas, Washington • (360) 817-5500



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 031000-E2875

ISSUE DATE: October 3, 2000

Page 1 of 3

Issued to: Square D Company
1601 Mercer Road
lexington, KY. 40511 USA

Report Reference: E2875, March 4, 1998


This is to Certify that
representative samples of: Enclosed Switches, types H221, H321, H361 and H361, suitable for use as
service equipment. Catalog numbers may have suffix letters.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)
indicated on this Certificate.


Standard(s) for Safety: UL 98, Enclosed Switches

Additional Information: See Addendum

Only those products bearing the UL Listing Mark should be considered as being covered by
UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control
number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate
UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: 
Tom Skibbs
Underwriters Laboratories Inc.

Review Engineer: 
Jake Killinger
Underwriters Laboratories Inc.

A not-for-profit organization
dedicated to public safety and
committed to quality service



CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 031000-E2875
ISSUE DATE: October 3, 2000

Page 2 of 3

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

RATINGS


Current: 30 A maximum


Short Circuit: When used with Class J or R fuses, fusible switches are suitable for use
On circuits capable of delivering not more than 200,000 rms symmetrical
Amperes.

When used with Class H or K fuses, fusible switches are suitable for use
On circuits capable of delivering not more than 10,000 rms symmetrical
Amperes.

Unfused switches are suitable for use on circuits capable of delivering not
More than

- (a) 10,000 rms symmetrical amperes when protected by Class H or K fuses or
- (b) 100,000 rms symmetrical amperes when protected by Class J, T or R fuses.

Engineer: 
Tom Skibbs
Underwriters Laboratories Inc.

Review Engineer: 
Jake Killinger
Underwriters Laboratories Inc.



CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 031000-E2875
 ISSUE DATE: October 3, 2000

Page 3 of 3

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

	Amps	Volts(max)	Horsepower (+ indicates maximum rating)											
			Current		Alternating						Direct			
			Voltage	Phase	120	240	480	600	125	250	600			
H221	30	240ac/250dc	.5,	1.5,	3,							2,	5	-
			2+	3+	7.5+							3+		
H321	30	240ac/250dc	.5,	1.5,	3,							2,	5	
			2+	3+	7.5+							3+		
H361	30	600ac/600dc	.5,	1.5,	3,	3,	5,	3,	7.5	2,		5	10	
			2+	3+	7.5+	7.5+	15+	10+	20+	3+			15+	
HU361	30	600ac/600dc	2	5	10	7.5	20	10	30	3		5	15	

Engineer: *Tom Skibbs*
 Tom Skibbs
 Underwriters Laboratories Inc.

Review Engineer: *Jake Killinger*
 Jake Killinger
 Underwriters Laboratories Inc.