



Certificate of Compliance

Certificate: 1106492 (LR 29971)

Master Contract: 153555

Project: 70027706

Date Issued: April 13, 2015

Issued to: Schneider Electric USA, Inc.

Square D
3700 6th St SW
Cedar Rapids, IA 52404
USA
Attention: Manuel Salinas

The products listed below are eligible to bear the CSA Mark shown



R. Tateishi

Issued by: R. Tateishi, P. Eng.

PRODUCTS

CLASS 1432 02 - CIRCUIT BREAKERS - Arc Fault Circuit Interrupters

Combined circuit breaker and arc fault circuit interrupter, Types QO-AFI, QO-VHAFI, QOB-AFI, QOB-VHAFI, QO-CAFI, QO-VHCAFI, QOB-CAFI, QOB-VHCAFI, QO-PCAFI and QO-VHPCAFI, Series 1, single-pole, 15 and 20A, 120V ac.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures

TIL No. M-02A - Interim Requirements for Arc-Fault Circuit Interrupters



Supplement to Certificate of Compliance

Certificate: 1106492

Master Contract: 153555

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

| Project | Date | Description |
|----------------|--------------|--|
| 70027706 | Apr 13, 2015 | Addition of an alternate stationary contact. |
| 2734135 | Jun 18, 2014 | Addition of the Type QO-VHPCAFI circuit breakers. |
| 2541349 | Jul 3, 2012 | Addition of the Type QO-PCAFI. |
| 2530797 | Jun 12, 2012 | Addition of a new module, Model S1B26974 for use in the Types QO-AFI, QO-VHAFI, QOB-AFI and QOB-VHAFI. |
| 2171940 | May 1, 2009 | Software revisions to the microcontroller used in the Types QO-CAFI, QO-VHCAFI, QOB-CAFI and QOB-VHCAFI. |
| 1953221 | Jan 15, 2008 | Addition of a revised module for use in the Types QO-CAFI, QO-VHCAFI, QOB-CAFI and QOB-VHCAFI. |
| 1978291 | Nov 13, 2007 | Deletion of SWD rating and change in stationary contact material. |
| 1862776 | Dec 8, 2006 | Addition of Types QO/QOB-CAFI and QO/QOB-VHCAFI. |
| 1576590 | Jul 27, 2004 | Addition of alternate module (Model 48155-438-50). |

History

1382568 Jan. 28, 2004 Addition of Types QO-VHAFCI and QOB-VHAFCI.

1285231 Jan. 25, 2002 Addition of alternate cover and base material.

1232203 Aug. 29, 2001 Revised module.

1209887 May 30, 2001 Addition of alternate cover and base material.

1106492 Aug. 10, 2000 Combined circuit breaker and arc fault circuit interrupter, Type QO-AFCI and QOB-AFCI, Series 1, single-pole, 15 and 20A, 120V ac.