




SEISMIC QUANTIFICATION

TO BE COMPLIANT WITH THE SEISMIC REQUIREMENTS OF ASCE/SEI 7, THIS UNIT IS SELF CERTIFIED TO ICS ES AC156, BY SHAKE TABLE QUALIFICATION TESTING. THE ENCLOSURE ABOVE IS 22M.

TRANSFORMER SPECIFICATION

150 KVA 3 PHASE 60 HERTZ
 PRIMARY VOLTAGE: 480 DELTA
 SECONDARY VOLTAGE: 208Y/120
 115°C RISE ABOVE 40°C AMBIENT
 220°C INSULATION SYSTEM COPPER WINDING
 APPROXIMATE WEIGHT: 1303 LBS
 GUARANTEED SOUND LEVEL: 45 dB
 TYPE 2 ENCLOSURE PAINTED ANSI 49 GREY
 MINIMUM EFFICIENCY 98.74% @ 35% LOADING 75°C
 COMPLYING WITH DOE 2016-10 CFR 431
 (78 FR 23335-APRIL 18, 2013)

NOTES:




cULus List TO UL 1561 AND C22.2No47, FILE NUMBER E6868
 ALL UNITS 100% TESTED PRIOR TO SHIPPING TO NEMA ST-20 (2014)
 MANUFACTURE IN ISO 9001 FACILITIES
 GREEN PREMIUM (RoHS/REACH COMPLIANT, PRODUCT ENVIRONMENT PROFILE)
 REGISTERED TO DOE VIA 10 CFR 429 & NRCAN
 MINIMUM CLEARANCE 1/2 INCH PER ALCOVE TESTING UL 1561. SIDES AND REAR
 FRONT ACCESS MUST COMPLY WITH NEC WORK SPACE REQUIREMENTS,
 MINIMUM CLEARANCE OF 6 INCHES.
 CONDUIT ENTRY AREA ARE SHOWN ABOVE, LOCATIONS ARE FRONT SIDES
 AND FRONT BOTTOM

DUAL DIMENSIONS: INCHES
 MILLIMETERS

LOW VOLTAGE DISTRIBUTION TRANSFORMER
 DOE 2016
 DRY TYPE TRANSFORMERS CATALOG NO EXN150T3HFCU
 3 PHASE, 480 DELTA
 SECONDARY 208Y /120, COPPER

SQUARE D[™]
 by Schneider Electric


DWG# EXN150T3HFCU PG 1



IN EACH PHASE CONNECT TO TAPS	
PRIMARY VOLTS	2-2.5% FCAN 4-2.5% FCBN
504	1
492	2
480	3
468	4
456	5
444	6
432	7

NOTE: ACTUAL VOLTAGES &
NAMEPLATE VALUES MAY NOT
MATCH VOLTAGE IN TABLE

REVISAR ACOTAMIENTO DE TERMINALES Y BARRA CON TOM



DUAL DIMENSIONS: INCHES
MILLIMETERS

LOW VOLTAGE DISTRIBUTION TRANSFORMER
DOE 2016
DRY TYPE TRANSFORMERS CATALOG NO EXN150T3HFCU
3 PHASE, 480 DELTA
SECONDARY 208Y /120, COPPER

SQUARE D™
by **Schneider Electric**

DWG# EXN150T3HFCU PG 2
NO.