

IEC**IECEE**

Ref. Certif. No.

FR_722387**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Contacteur

Auxiliary Contact Blocks

Name and address of the applicant

SCHNEIDER ELECTRIC INDUSTRIES SAS35, rue Joseph Monier
92500 RUEIL-MALMAISON - FRANCE

Name and address of the manufacturer

SCHNEIDER ELECTRIC INDUSTRIES SAS35, rue Joseph Monier
92500 RUEIL-MALMAISON - FRANCE

Name and address of the factory

CROUZET INDUSTRY (HUIZHOU) LTD3rd Floor, No. 6, Huifeng West 2nd Road, Zhongkai Hi-tech
Industrial Development Zone, Huizhou
Guangdong, 516006 - CHINA

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

LAG8N, LAE8N

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_711532 dated 07/06/2021.
Update further to the evolution of the standard(s)
Addition of product references Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020
IEC 60947-5-1:2024

As shown in the Test Report Ref. No. which forms part of this Certificate

25119Y90041

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE

33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCEwww.lcie.fr

Date: 26/08/2025

Signature: 
Gilles LEMONNIER
Certification Officer

ANNEX

References, ratings and main characteristics:

Kind of switching elements	Auxiliary contacts of a switching device
Type of contact elements	X, Zb
Number of poles	1NO +1NC, or 2NO
Kind of current	AC and DC
Method of operations	electromagnetic
Rated operational voltage Ue (V)	AC120V, 600V DC125V,250V
Rated insulation voltage Ui (V)	600V
Rated impulse withstand voltage Uimp (kV)	6kV
Conventional free air thermal current Ith (A)	10A
Rated operational current Ie (A)	AC-15: Ue/Ie: AC120V/6A, AC600V/1,2A DC-13: Ue/Ie: DC125V/1,1A, DC250V/0,55A
Rated frequency (Hz)	50/60Hz
Utilization category	AC-15, DC-13
Rated conditional short-circuit current (kA)	1kA
Kind of protective device	Fuse 10A gG
IP code	IP20
Pollution degree	3

Type explanation

<u>LAG8N</u>	<u>11</u>	<u>3</u>	<u>P</u>
I	II	III	IV

I-	Product basic designation: LAG8N auxiliary contact block LAE8N auxiliary contact block
II-	Contact arrangements: 11: 1NO+1NC 20: 2NO
III-	Type of connection: Blank: clamps and screws. 3: spring connection version
IV-	Terminal marking identification numbers Blank: standard P: Terminal identification markings conforming to EN50012 standard



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 26/08/2025

Signature:  Gilles LEMONNIER

