

CERTIFICATE OF COMPLIANCE

Certificate Number E48340
Report Reference E48340-20200214
Issue Date 2020-FEBRUARY-12

Issued to: Schneider Electric USA, Inc.
3700 6th St Sw
Cedar Rapids IA 52404-5403

**This certificate confirms that
representative samples of**

CIRCUIT BREAKERS WITH GROUND-FAULT CIRCUIT
INTERRUPTER AND COMBINATION-TYPE ARC-FAULT
CIRCUIT INTERRUPTER PROTECTION

Type QO and QOP. Series 1
Type HOM, HOMP, CHOM & CHOMP. Series 1

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 489, MOLDED-CASE CIRCUIT BREAKERS, MOLDED-
CASE SWITCHES, AND CIRCUIT-BREAKER
ENCLOSURES

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

