




Ref. Certif. No.

DK-84461-M1-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Harmony Safety Module XPSU and XPSB
Name and address of the applicant	SCHNEIDER ELECTRIC AUTOMATION GMBH SCHNEIDERPLATZ 1 MARKTHEIDENFELD 97828 GERMANY
Name and address of the manufacturer	SCHNEIDER ELECTRIC AUTOMATION GMBH SCHNEIDERPLATZ 1 MARKTHEIDENFELD 97828 GERMANY
Name and address of the factory	PT. Schneider Electric Manufacturing Batam JL Beringin Lot 208, 16A BIP Muka Kuning Kel. Muka kuning Kec., Sungai Beduk, Batam, 29433, Indonesia
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See Page 2
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	XPSUAB*1C**, XPSUAF*3A**, XPSUAK*2A**, XPSUS*2A**, XPSUAT*3A3A** <input checked="" type="checkbox"/> Additional Information on page 2
Additional information (if necessary may also be reported on page 2)	The report was revised to include technical modifications. <input checked="" type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-5-1:2016, IEC 60947-1:2007, IEC 60947-1:2007/AMD1:2010, IEC 60947-1:2007/AMD2:2014
As shown in the Test Report Ref. No. which forms part of this Certificate	4789614749 issued on 2021-04-14

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Denko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2021-05-19
Original Issue Date: 2019-06-11

Signature:
Jan-Erik Storgaard



Ref. Certif. No.

DK-84461-M1-UL

Additional Model(s):

Series: XPSUAB*1C**, XPSUAF*3A**, XPSUAK*2A**, XPSUS*2A**, XPSUAT*3A3A**, XPSUDN*3A**, XPSUEP*4A**, XPSUVN*1A**, XPSBAT12A1A**, XPSBAC*4A**,

* = Power Supply:

1 = 24 Vac/Vdc.

3 = 48 – 240 Vac/Vdc.

** = Terminal Type:

C = Pluggable connector with cage clamp (Screwless Terminal)

P = Pluggable connector with screw clamp (Screw Terminal)

See test report for Nomenclature

Ratings:

Power Supply:

• 24 V ac/dc

• 48-240 V ac/dc Outputs:

Outputs:

• AC-15 : 250 Vac, NO 3 A, NC 1 A

• DC-13 : 24 Vdc, NO 3 A, NC 1 A

(Except XPSUAB*1C**: DC-13: 24 Vdc, NO 2 A, NC 1 A)

IP40 for housing

IP 20 for terminals.

Summary of Modifications:

The original report was modified to include the following changes:

Add new models, add new relay;

Test item particulars and standard information have been revised;

Model designation was revised.

Additional information (if necessary)



UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA

UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK

UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN

UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2021-05-19

Original Issue Date: 2019-06-11

Signature:

Jan-Erik Storgaard