



Certificate of Compliance

Certificate: 1542878

Master Contract: 153555

Project: 80044433

Date Issued: 2021-01-27

Issued To: Schneider Electric USA, Inc. Square D
3700 6th St SW
Cedar Rapids, Iowa, 52404
United States

Attention: Jerry Beasler

The products listed below are eligible to bear the CSA Mark shown

Issued by: *Reddi Cheekoori*
Reddi Cheekoori



PRODUCTS

CLASS - C143201 - CIRCUIT BREAKERS Moulded Case Type

Moulded case circuit breakers, Powerpact M with suffix G and J, 2- and 3-pole, 800A, 600V ac max.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No.5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures



Supplement to Certificate of Compliance

Certificate: 1542878

Master Contract: 153555

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80044433	2021-01-27	Update to the report 1542878 to include Type ET 1.0LI Trip Unit and alternate cover material to Powerpact M breakers
000070021092	2015-01-21	Update to Report 1542878 to cover RoHS compliant trip units
000070011192	2014-09-05	Update to Report
0002554568	2012-10-17	Addition of wire connector kits.
0001542878	2004-03-30	Original Certification.