

# Certificate of Compliance

Certificate Number 20091130 – E181374  
Report Reference E181374, 2009 November 12  
Issue Date 2009 November 30

Page 1 of 1



*Issued to:* **SQUARE D CO**  
3700 6TH ST SW  
CEDAR RAPIDS, IA 52404 USA

*This is to certify that  
representative samples of*

## **Circuit Breakers with Equipment Ground-fault Protection**

**Model Descriptions:** Molded-Case 3 Pole Circuit Breaker with equipment ground fault protection, Types QO and QOB, Series 1.

*Have been investigated by Underwriters Laboratories Inc.® in accordance with  
the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:*

The basic standards used to investigate products in this category are ANSI/UL 489, "Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures," ANSI/UL 1053, "Ground-Fault Sensing and Relaying Equipment" and CAN/CSA-C22.2 No. 5-2002, "Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures" and CAN/CSA-C22.2 No. 144-1991, "Ground Fault Circuit Interrupters."


*Additional Information:*

This device is a three-pole circuit breaker which incorporates ground fault sensing and relaying equipment with a 30 mA or 100mA trip level and is rated 15, 20, 30 A, 40 A and 50 A, 208Y/120 VAC & 240 VAC, 60 Hz.

Catalog number designation EPD has a ground fault threshold of 30mA  
Catalog number designation EPE has a ground fault threshold of 100mA

There circuit breakers maybe accessorized with an Auxiliary Switch, contact type A or B, or an Alarm Switch.

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

**William Carney**  
Director, North American Certification Programs