

## Declaration of Conformity

Issued by Manufacturer  
Hoffman Enclosures, Inc.  
2100 Hoffman Way, Anoka, Minnesota 55303-1745, U.S.A.  
declare at our sole responsibility, that these devices are designed and constructed according to  
the fundamental safety and health requirements.

Enclosure Models: AST\*\*\*\*R (Bulletin S90T)  
Equipment Description: Hoffman Splitter Trough, Type 1  
Enclosure Rating : CSA Type 1  
Enclosure Certification: CSA C22.2 No. 76-14

### PRODUCTS

CLASS 4662 02 - WIREWAYS AND BUSWAYS - Splitters

Splitter troughs in a general-purpose, sheet steel (Type 1) enclosure; Cat. Number Series ASTXXX3R and ASTXXX4R; containing terminal blocks suitable for copper only 3 or 4 wires, rated 85 to 225 Amp, 600 Vac max.

Splitter troughs in a general-purpose, sheet steel (Type 1) enclosure; Cat. Number Series ASTXXX3R and ASTXXX4R; containing terminal blocks suitable for copper only 3 or 4 wires, rated 400 to 600 Amp, 600 Vac max.

Applicable Standards: CAN/CSA C22.2 No. 76-14 – Splitters  
CAN/CSA C22.2 No. 26-13 – Construction and Test of Wireways,  
Auxiliary Gutters, and Associated Fittings

Authorized by:



5/22/2020 (today's date)

Glen Kampa

Date

Senior Regulatory Engineer

Subject to Change Without Notice

DOC: CERT-00270-B



# Certificate of Compliance

Certificate: 70074096

Master Contract: 151630 (042184\_C\_000)

Project: 70177570

Date Issued: 2018-04-25

Issued to: Hoffman Enclosures Inc.  
2100 Hoffman Way  
Anoka, Minnesota 55303-1745  
USA  
Attention: Glen Kampa

*The products listed below are eligible to bear the CSA Mark shown*



Issued by: *Frank Gessner*  
Frank Gessner

## PRODUCTS

### CLASS 4662 02 - WIREWAYS AND BUSWAYS - Splitters

Splitter troughs in a general-purpose, sheet steel (Type 1) enclosure; Cat. Number Series ASTXXX3R and ASTXXX4R; containing terminal blocks suitable for copper only 3 or 4 wires, rated 85 to 225 Amp, 600 Vac max.

Splitter troughs in a general-purpose, sheet steel (Type 1) enclosure; Cat. Number Series ASTXXX3R and ASTXXX4R; containing terminal blocks suitable for copper only 3 or 4 wires, rated 400 to 600 Amp, 600 Vac max.

## APPLICABLE REQUIREMENTS

- CSA C22.2 No. 76-14 - Splitters
- CSA C22.2 No. 26-13 - Construction and Test of Wireways, Auxiliary Gutters, and Associated Fittings