



Certificate of Compliance

Certificate: 1484042 (LL 89328-2)

Master Contract: 158337

Project: 80025440

Date Issued: 2019-11-26

Issued To: Schneider Electric USA, Inc. Square D
Distribution Equipment Business
1601 Mercer Rd
Lexington, Kentucky, 40511
United States

Attention: Manuel Salinas

The products listed below are eligible to bear the CSA Mark shown

Issued by: *Ron Tateishi*
Ron Tateishi



PRODUCTS

CLASS 4631 01 – SERVICE EQUIPMENT – Combination Service Entrance Equipment

Combination service entrance panelboards; circuit breaker type with main circuit breaker, Type QO, Catalogue No. CQO, 1-ph, 2- or 3-wire, 120/240, 120/208V ac max, 225A max, 60 branch poles max, 80 circuits max.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 29 - Panelboards and Enclosed Panelboards