



Ref. Certif. No.

FR_721586

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Air circuit-breaker

Name and address of the applicant

SCHNEIDER ELECTRIC INDUSTRIES SAS
35, rue Joseph Monier, 92500 RUEIL-MALMAISON - FRANCE

Name and address of the manufacturer

SCHNEIDER ELECTRIC INDUSTRIES SAS
35, rue Joseph Monier, 92500 RUEIL-MALMAISON - FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF2

Model / Type Ref.

MasterPact MTZ1 Type H1, H2, H3 and L1
Circuit-breakers equipped with electronic control units:
Micrologic X: 2.0 X - 5.0 X - 6.0 X - 7.0 X
Micrologic Xi: 5.0 Xi - 6.0 Xi
MicroLogic Active: 2.0 A - 5.0 A - 6.0 A - 2.0 E - 5.0 E - 6.0 E -
2.0 AP - 5.0 AP - 6.0 AP - 2.0 EP - 5.0 EP - 6.0 EP-6.0Ei
See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_713511/M3 dated 14/10/2024.
Addition of product references
Technical modification

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016 +A1:2019
IEC 60947-1:2007 +A1:2010 +A2:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

25119Y90011


This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 09/05/2025

Signature: 
Certification Officer



IEC

IECEE

®

™

Ref. Certif. No.

FR_721586

ANNEX

Name and address of the factories:

SCHNEIDER ELECTRIC Alpes

Zone d'activités Alpespace, Rue Isaac Newton, 73800 Porte-de-Savoie - FRANCE

Schneider Electric India Pvt Ltd

SURVEY NO 215, GAGILLAPUR VILLAGE, MEDAK ROAD, RANGAREDDY DISTRICT
HYDERABAD, 500 043 (A.P.) - INDIA

SCHNEIDER SHANGHAI POWER DISTRIBUTION ELEC. APP. Co. Ltd

No.833 Kangqiao Road, Kangqiao Industrial Development Zone Pudong District, 201315 SHANGHAI - CHINA



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE

33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Date: 09/05/2025

Signature: 
Julien GAUTHIER
Certification Officer



ANNEX

References, ratings and main characteristics:

Models				Rated current (In)
MTZ1-06 H1	MTZ1-06 H2	MTZ1-06 H3	MTZ1-06 L1	400 to 630A
MTZ1-08 H1	MTZ1-08 H2	MTZ1-08 H3	MTZ1-08 L1	400 to 800A
MTZ1-10 H1	MTZ1-10 H2	MTZ1-10 H3	MTZ1-10 L1	400 to 1000A
MTZ1-12 H1	MTZ1-12 H2	MTZ1-12 H3	-	630(1) to 1250A
MTZ1-16 H1	MTZ1-16 H2	MTZ1-16 H3	-	630(1) to 1600A

(1) 400A WITH MICROLOGIC ACTIVE CONTROL UNIT

Selectivity category	B (type H1, H2, H3) A (type L1)
Interruption medium	Air
Design	Moulded case
Method of controlling the operating mechanism	Stored energy operation
Suitability for isolation	Suitable
Provision for maintenance	Maintainable
Method of installation	Fixed & withdrawable
Type of release	Electronic Micrologic X: 2.0 X – 5.0 X – 6.0 X – 7.0 X Micrologic Xi: 5.0 Xi – 6.0 Xi MicroLogic Active: 2.0 A - 5.0 A - 6.0 A - 2.0 E - 5.0 E - 6.0 E - 2.0 AP - 5.0 AP - 6.0 AP - 2.0 EP - 5.0 EP – 6.0 EP - 6.0Ei
Rated operational voltage U_e : (V)	H1, H2: 220V, 415V, 440V, 525V, 690V H3: 220V, 415V, 440V L1: 220V, 415V, 440V, 525V
Rated insulation voltage U_i : (V)	1000V
Rated impulse withstand voltage U_{imp} : (kV)	12kV
Rated current I_n : (A)	See above table
Conventional free air thermal current I_{th} : (A)	Equal to I_n
Rated current for four pole circuit-breakers : (A)	Equal to I_n
Rated frequency : (Hz)	50/60Hz
Nature of supply :	AC
Total number of poles :	3P, 4P
Number of protected poles :	3P,4P
Rated duty	uninterrupted duty
Rated ultimate short-circuit breaking capacity I_{cu} : (kA)	H1: 42kA - 220/415/440/525/690V H2: 50kA - 220/415/440V; 42kA - 525/690V H3: 66kA - 220/415/440V L1: 150kA - 220/415V; 130kA - 440V; 100kA - 525V
Rated service short-circuit breaking capacity I_{cs} : (kA)	H1: 42kA - 220/415/440/525/690V H2: 50kA - 220/415/440V; 42kA - 525/690V H3: 50kA - 220/415/440V L1: 150kA - 220/415V; 130kA - 440V; 100kA - 525V
Rated short-time withstand current I_{cw} : (kA)	H1, H2: 42kA/1s, 24kA/3s H3: 50kA/1s, 30kA/3s L1: N/A
Electromagnetic compatibility (EMC)	Environment A
Circuit-breaker for use in IT systems	H1, H2: $I_{IT} = 19.2$ kA - 690 V H3: $I_{IT} = 19.2$ kA - 440 V L1: $I_{IT} = 12$ kA - 525 V
Special tests according Annex Q – IEC60947-1 : Tests for environmental categories	Category D



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 09/05/2025

Signature: 
 LABORATOIRE CENTRAL DES
 INDUSTRIES ELECTRIQUES
 S.A.S au capital de 15.745.984 €
 RCS Nanterre B 388 527 123
 33 AVENUE DU GENERAL LECLERC
 92260 FONTENAY-AUX-ROSES
 Certification Officer

ANNEX

Undervoltage release (MN), shunt trip release (MX), closing release (XF)

References	Voltage - Type - Frequency	References	Voltage - Type - Frequency
MN		MN Diag.	
LV833668 LV833668SP	24-30V DC ; 24V AC 50/60 Hz	LV836668 LV836668SP	24-30V DC ; 24V AC 50/60 Hz
LV833669 LV833669SP	48-60V DC ; 48V AC 50/60 Hz	LV836669 LV836669SP	48-60V DC ; 48V AC 50/60 Hz
LV833670 LV833670SP	100-130V DC ; 100-130V AC 50/60 Hz	LV836670 LV836670SP	100-130V DC ; 100-130V AC 50/60 Hz
LV833671 LV833671SP	200-250V DC ; 200-250V AC 50/60 Hz	LV836671 LV836671SP	200-250V DC ; 200-250V AC 50/60 Hz
LV833673 LV833673SP	380-480V AC 50/60 Hz	LV836673 LV836673SP	380-480V AC 50/60 Hz
33668 LV933668SP	24-30V DC ; 24V AC 50/60 Hz		
33669 LV933669SP	48-60V DC ; 48V AC 50/60 Hz		
33670 LV933670SP	100-130V DC ; 100-130V AC 50/60 Hz		
33671 LV933671SP	200-250V DC ; 200-250V AC 50/60 Hz		
33673 LV933673SP	380-480V AC 50/60 Hz		
MX/XF			
LV833659 LV833659SP	24-30V DC ; 24V AC 50/60 Hz	LV833033 LV833033SP	24-30V DC ; 24V AC 50/60 Hz
LV833660 LV833660SP	48-60V DC ; 48V AC 50/60 Hz	LV833034 LV833034SP	48-60V DC ; 48V AC 50/60 Hz
LV833661 LV833661SP	100-130V DC ; 100-130V AC 50/60 Hz	LV833035 LV833035SP	100-130V DC ; 100-130V AC 50/60 Hz
LV833662 LV833662SP	200-250V DC ; 200-250V AC 50/60 Hz	LV833036 LV833036SP	200-250V DC ; 200-250V AC 50/60 Hz
LV833663 LV833663SP	277V AC 50/60 Hz	LV833037 LV833037SP	277V AC 50/60 Hz
LV833664 LV833664SP	380-480V AC 50/60 Hz	LV833038 LV833038SP	380-480V AC 50/60 Hz
33659 LV933659SP	24-30V DC ; 24V AC 50/60 Hz		
33660 LV933660SP	48-60V DC ; 48V AC 50/60 Hz		
33661 LV933661SP	100-130V DC ; 100-130V AC 50/60 Hz		
33662 LV933662SP	200-250V DC ; 200-250V AC 50/60 Hz		
33663 LV933663SP	277V AC 50/60 Hz		
33664 LV933664SP	380-480V AC 50/60 Hz		



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 09/05/2025

Signature: 
Julien GAUTHIER
 Certification Officer



ANNEX

Electric motor (MCH)

References	Voltage - Type - Frequency	
33186 LV833186SP	48 V	AC 50/60 Hz
33176 LV833176SP	100-130 V	
33177 LV833177SP	200-240 V	
33179 LV833179SP	277-415 V	
33179 LV833179SP	440-480 V	
33193 LV833193SP	+ resistor	
33185 LV833185SP	24-30 V	DC
33186 LV833186SP	48-60 V	
33187 LV833187SP	100-130 V	
33188 LV833188SP	200-250 V	

Others

Embedded Ethernet InterFace (EIFE): LV851001, LV851100SP, LV851001SP
 ULP interface module: LV836385, LV850063SP, LV836386, LV850064SP
 M2C - Programmable contacts: LV847086, LV847086SP
 ESM - ERMS Switch Module: LV836300, LV836300SP
 Rectangular sensor for earth-leakage protection: LV833573SP
 Electrical reset (RES): 47082, LV847344FS, 47083, LV847345FS



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 09/05/2025

Signature: 
Julien GAUTHIER
 Certification Officer

