



Ref. Certif. No.

FR_715629

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Contacteur
AC Contacteur

Name and address of the applicant

SCHNEIDER ELECTRIC INDUSTRIES SAS
35, rue Joseph Monier
92500 RUEIL MALMAISON - FRANCE

Name and address of the manufacturer

SCHNEIDER ELECTRIC INDUSTRIES SAS
35, rue Joseph Monier
92500 RUEIL MALMAISON - FRANCE

Name and address of the factory

SCHNEIDER ELECTRIC A.S.
Cizovska 447
39701 PISEK - CZECH REPUBLIC

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

LC1SK0600, LP1SK0600, LC1SKGC200,
LC1SKGC310, LC1SKGC301, LC1SKGC400
accessories: LA1SK01, LA1SK10

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_709832 dated 14/12/2020.
Addition of product references

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2007 +A1:2010 +A2:2014
IEC 60947-4-1:2018
IEC 60947-5-1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

2011990029-01, 2011990029-02,
2011990029-01-M1, 2011990029-02-M1

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 28/09/2022



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature:
Julien GAUTHIER
Certification Officer

ANNEX

References, ratings and main characteristics:

Ui	690V					
Uimp	6kV					
Ith	20A(LC1SKGC...), 12A(LC1&LP1SK0600)					
Utilization category	AC-1,AC-3					
Ue/le	LC1SK0600: AC-1: Ue/le: 690V/12A ; AC-3: Ue/le: 400V/6A					
	LP1SK0600: AC-1: Ue/le: 690V/12A ;					
	LC1SKGC200: AC-1: Ue/le: 690V/20A ; AC-3: Ue/le: 400V/5A					
	LC1SKGC310,LC1SKGC301,LC1SKGC400: AC-1: Ue/le: 690V/20A ; AC-3: Ue/le: 400V/9A					
Us	LC1SK...: AC 50/60Hz: 24V,48V,110V,120V,220V,230V,240V,380V,400V LP1SK0600...: DC12V, 24V,36V,48V,72V <u>Coil type Code:</u> AC (all except LP1SK0600): B7, E7, F7, G7, M7, P7, U7, Q7, V7 DC (LP1SK0600) : JD, BD, CD, ED, SD					
"I" Current						
	Model type	Ue max (V)	le max (A)	Type fusible IEC	Calibre Fusible (A)	"I" current (kA)
	LC1SK0600	690	12	gG 22x58 – 690V	16	1
		400	6	gG 14x51 – 500V	12	1
				aM 14x51 – 500V	6	1
	LC1SKGC310, LC1SKGC301, LC1SKGC400	690	20	gG 22x58 – 690V	20	3
		400	9	gG 14x51 – 500V	20	1
				aM 14x51 – 500V	10	1
	LP1SK0600	690	12	gG 22x58 – 690V	16	1
	LC1SKGC 200	690	20	gG 22x58 – 690V	20	3
		400	5	gG 14x51 – 500V	12	1
				aM 14x51 – 500V	6	1



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 28/09/2022



Signature: *Julien GAUTHIER*
Certification Officer


ANNEX

"q" Current	Equal to "r" current
Number of poles	LC1SK0600, LP1SK0600, LC1SKGC200: 2P LC1SKGC310: 3P + NO Aux contact, LC1SKGC301:3P + NC Aux contact LC1SKGC400: 4P
Auxiliary circuits	LA1SK10(1x NO), LA1SK01(1x NC), apply to LC1SK0600 LC1SKGC310 (1x NO) and LC1SKGC301 (1xNC) models Ith: 10A AC-15: Ue/Ie: 120V/6A; 440V/1,64A DC-13: Ue/Ie: 125V/0,55A; 600V/0,1A 1NO or 1NC



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 28/09/2022



Julien GAUTHIER
Certification Officer