



中国国家强制性产品认证证书

证书编号: 2024010304660705

认证委托人名称及地址

施耐德电气(中国)有限公司上海分公司
上海市普陀区绥德路 669 号

生产者名称及地址

Schneider Electric Industries SAS
35 Rue Joseph Monier, 92500 Reuil-Malmaison France

生产企业名称及地址

PT. Schneider Electric Manufacturing Batam
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning
Kel. Muka Kuning Kec. Sungai Beduk - Batam, Indonesia

产品名称和系列、型号、规格

软起动器

ATS430D17S6、ATS430D32S6、ATS430D47S6Ui: 600V;Uimp: 6kV;Ue:
AC208-600V;Ith=Ie:17A(ATS430D17S6);32A(ATS430D32S6);47A(ATS430D47S6);使用类别:
AC-53a;极数: 3P;额定功率(Pe):ATS430D17S6: 4kW(230V), 7.5kW(400V), 7.5kW(440V),
9kW(500V); ATS430D32S6: 7.5kW(230V), 15kW(400V), 15kW(440V),
18.5kW(500V);ATS430D47S6: 11kW(230V), 22kW(400V), 22kW(440V), 30kW(500V); 外壳防护
等级: IP20

产品标准和技术要求

GB/T 14048.6-2016

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024)的要求, 特发此证。

发证日期: 2024 年 07 月 19 日 有效期至: 2029 年 07 月 18 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010304660705

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric (China) Co. Ltd. Shanghai Branch
No. 669, Suide Road, Putuo District, Shanghai, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Industries SAS
35 Rue Joseph Monier, 92500 Rueil-Malmaison France

NAME AND LOCATION OF THE FACTORY

PT. Schneider Electric Manufacturing Batam
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning
Kec. Sungai Beduk – Batam, Indonesia

PRODUCT NAME,MODEL AND SPECIFICATION

Soft Starter

ATS430D17S6、ATS430D32S6、ATS430D47S6Ui: 600V;Uimp: 6kV;Ue:
AC208-600V;Ith=Ie:17A(ATS430D17S6);32A(ATS430D32S6);47A(ATS430D47S6);Utilization Category: AC-53a;pole:
3P;(Pe):ATS430D17S6: 4kW(230V), 7.5kW(400V), 7.5kW(440V), 9kW(500V); ATS430D32S6: 7.5kW(230V),
15kW(400V), 15kW(440V), 18.5kW(500V);ATS430D47S6: 11kW(230V), 22kW(400V), 22kW(440V), 30kW(500V);
IP20

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.6-2016

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jul.19,2024

Valid until: Jul.18,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

