



Product Service

CERTIFICATE

No. Z10 128850 0001 Rev. 00

Holder of Certificate: **Schneider Electric Industries SE**
33 rue André Blanchet
27120 Pacy-sur-Eure
FRANCE

Certification Mark:



Product: **Safety components**

Model(s): **ATS 490**

Parameters: SIL 1
SILCL 1
Cat2, PLc
Power supply: 208-690V
Working temperature (functional): -25°C - +40°C
Working temperature (STO/SS1): -25°C - +60°C

The report listed below and the user documentation are mandatory part of this certificate. The certified components are listed in report S2103710T in the currently valid revision.

Tested according to: 2006/42/EC
IEC 61508-1:2010
IEC 61508-2:2010
IEC 61508-3:2010
IEC 62061:2021
ISO 13849-1:2023
UL 61800-5-2:2022
IEC 61800-5-2:2016

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: S2103710T
Valid until: 2029-10-16

Date, 2024-10-17

(Thomas Kreten)