



Ref. Certif. No.

CN47538

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Auxiliary Contact Blocks

Name and address of the applicant

Schneider Electric Industries SAS
31 rue Pierre Mendès-France 38320 EYBENS, France

Name and address of the manufacturer

Schneider Electric Industries
Zone industrielle les Agriers 16021 Angouleme France

Name and address of the factory

Schneider Electric Industries
Zone Industrielle les Agriers 16021 Angouleme France

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Uimp:4kV; Ui:250V; Ith: 5A(LUFN),2A(LUFW); Ue/Ie:
LUFN:AC-15:AC240V/1.5A; DC-13:DC250V/0.55A;
LUFW: AC-15:AC240V/1.5A; DC-13:DC250V/0.27A;
IP20(associated with Power Bases LUB)

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

LUFN, LUFW

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-5-1:2016(4th Edition)

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2018CQC-083938

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>



Date: Aug.09,2019

Signature:

Lu Mei

CB 0053625