



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 101000-E2875F

ISSUE DATE: October 10, 2000

Page 1 of 2

Issued to: Square D Company
1601 Mercer Road
Lexington, KY. 40511 USA

Report Reference: E2875, September 3, 1975


This is to Certify that representative samples of: Enclosed switches, types H221, H222, H321, H322, H361, H362, H462, HU461, HU462, HU361, HU362, H661, H662, HU661 & HU662, suitable for use as service equipment. Catalog numbers may have suffix letters.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 98, Enclosed Switches


Additional Information: See Addendum

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: 
Tom Skibbs
Underwriters Laboratories Inc.

Review Engineer: 
Jake Killinger
Underwriters Laboratories Inc.



CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 101000-E2875F
ISSUE DATE: October 10, 2000

Page 2 of 3

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

RATINGS

Current - 30 A & 60 A


Short Circuit When used with Class J or R fuses, fusible switches are suitable for use on circuits capable of delivering not more than 200,000 rms symmetrical amperes.


When used with Class H or K fuses, fusible switches are suitable for use on circuits capable of delivering not more than 10,000 rms symmetrical amperes.

Unfused switches are suitable for use on circuits capable of delivering not more than 200,000 rms symmetrical amperes when protected by Class J, T or R fuses.

Unfused switches are suitable for use on circuits capable of delivering not more than 10,000 rms symmetrical amperes when protected by Class H or K fuses.

Horsepower Ratings (see next addendum page)

Engineer: 
Tom Skibbs
Underwriters Laboratories Inc.

Review Engineer: 
Jake Killinger
Underwriters Laboratories Inc.

CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER:

Page 2 of 3

ISSUE DATE:

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Catalog No.	Horsepower Ratings (+ indicates maximum rating)															
	Current			Alternating									Direct			
	Voltage 120			240			480			600			125	250	600	
	Phase 1	2	3	1	2	3	1	2	3	1	2	3	--	--	--	
	Wires 2	4	3	2	4	3	2	4	3	2	4	3	2	2	2	
H221-2	1.5, 3+														5	
H222				3, 10+											10	
H222N	1.5, 3+			3, 10+		7.5, 15+							5		10	
H322						7.5, 15+									10	
H322N	1.5, 3+			3, 10+		7.5, 15+							5		10	
H321-2				3, 7.5+											5	
H361-2	1.5, 3+								5, 15+				7.5, 20+	2	5	10, 15+
H361	1.5, 2+			1.5, 3+		3, 7.5+	3, 7.5+		5, 15+				7.5, 20+	2	5	
H362, -N	1.5, 3+			3, 10+		7.5, 15+	5, 20+		15, 30+	10, 25+			15, 50+	5	10	25, 30+
HU361	2			5		10	10		20	15			30	2	5	
HU362	5			10		20	25		50	30			60	5	10	30
H461				3, 10+		3, 7.5+		7.5, 20+	5, 15+		10, 25+		7.5, 20+	2, 3+	5	10, 15+
H462				7.5, 20+		7.5, 15+		15, 40+	15, 30+		20, 50+		15, 50+	5	10	25, 30+
HU461				10		10		20	20		25		30	2	5	10
HU462				20		20		40	50		50		60	5	10	30
H661						3, 7.5+			5, 15+				7.5, 20+			
H662						7.5, 15+			15, 30+				15, 50+			
HU661						10			20				30			
HU662						20			50				60			

[Signature]
Engineer:

[Signature]
Review Engineer: