



Certificate: 70203979

Master Contract: 225619

Project: 80224870

Date Issued: 2024-09-17

Model(s)	Supply Voltage
ZBY9W	Illuminated supply: 24 Vac/dc, or 120 Vac, or 230 Vac

Cat. No. ZBY9W followed by one digit, followed by B, G or M, followed by three or four digits.

Illuminated pushbuttons, enclosed complete unit with contact block

Model(s)	Supply Voltage	Type	Contact Rating
XALK84W, XALK178W, XALK188W	Illuminated: 24 Vac/dc or 230 Vac	Contact Block: ZEN-L	A600 and R300

Cat. No. XALK84W or XALK178W or XALK188W followed by one digit, followed by B or M, may be followed by three digits, followed by E or G, may be followed by 1 digit, followed by H7.

Accessories: Labels for emergency-stop pushbutton

Model(s)
ZBY8L

Cat. No. ZBY8L followed by three or four digits.

Notes:

1. These open type devices are Certified only for use in complete assemblies where the suitability of the combination is subject to further investigation.
2. The complete unit is provided with a minimum of 1 N/C contact; the additional N/O or N/C contacts for multiple contact installations are optional.
3. These devices are suitable for enclosure type 1, 2, 3, 4, 4X, 12 or 13.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 60947-1:22 (Third edition) - Low-voltage switchgear and controlgear — Part 1: General rules

CSA C22.2 NO. 60947-5-1-14 - Low-voltage switchgear and controlgear - Part 5-1: Control circuit devices and switching elements - Electromechanical control circuit devices - First Edition

CSA C22.2 No. 14-18+Upd.1 (Thirteenth Edition)(R2022) - Industrial control equipment - Thirteenth Edition; Update No. 1: June 2022



Certificate: 70203979


Master Contract: 225619

Project: 80224870

Date Issued: 2024-09-17

Notes:

Products certified under Class(es) C321103, C321123 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 70203979

Master Contract: 225619

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80224870	2024-09-17	Update of report 225619-70203979 covers the new catalog number XALK188W for the Emergency Stop pushbutton (alternate configuration) and evaluates the report against the latest requirements of CSA C22.2 No. 60947-1 and CSA C22.2 No. 14-18 (Up.1) as per certification notices No. 78 and 82.
80091560	2021-09-01	Update CSA report 225619-70203979. Adding antibacterial additive.
70203979	2019-03-22	CSA Certification Illuminated Pushbuttons for E-Stop, complete unit Cat. No. XB5AS84W with contact block Type ZBE rating codes A600 and Q600, Operating heads Cat. No. ZB5AS84W, Illuminated rings Cat. No. ZBY9W, Enclosed complete unit Cat. No. XALK84W or XALK178W with contact block Type ZEN-L rating codes A600 and R300, Labels Cat. No. ZBY8L; suitable for enclosure type 1, 2, 3, 4, 4X, 12 or 13.