



**Underwriters Laboratories Inc.®**

Northbrook, Illinois • (847) 272-8800

Melville, New York • (516) 271-6200

Santa Clara, California • (408) 985-2400

Research Triangle Park,  
North Carolina • (919) 549-1400

Camas, Washington • (360) 817-5500

## **CERTIFICATE OF COMPLIANCE**

**CERTIFICATE NUMBER:** 210497-E84967B  
**ISSUE DATE:** April 21, 1997

**Issued to:** Square D Company  
3700 6th Street S. W.  
Cedar Rapids, IA 52404-3069, USA

**Report Reference:** E84967, November 10, 1989

**This is to Certify that representative samples of:**  
Molded Case Circuit Breakers  
Type HOM Series 1

Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 489, Molded Case Circuit Breakers and Circuit Breaker Enclosures

**Additional Information:** These are one and two pole circuit breakers, rated from 15A through 50A, 1 pole and 15A through 70A, 2 pole.  
Current Interrupting Rating is as follows:  
10,000A, 120/240 Vac, 1phase, 50/60 Hz.  
Uses wires rated as follows:  
60 or 75 Deg. C for 15-30A and 75 Deg. C only for 35-70A  
Notes: May be marked "Listed HACR Type".  
15 & 20A, 1 pole breakers may be marked "SWD".

**Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.**

The UL Listing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" (UL); the word "Listed"; a control number (may be alphanumeric) assigned by UL; and the product or category name (product identifier), as indicated in the appropriate UL Directory.

**LOOK FOR THE UL LISTING MARK ON THE PRODUCT**

**Engineer:** *Lawrence Smith*  
Underwriters Laboratories Inc.  
Lawrence Smith

**Review Engineer:** *Art Karamagianis*  
Underwriters Laboratories Inc.  
Art Karamagianis