



Underwriters Laboratories Inc.®

Northbrook, Illinois • (847) 272-8800
Melville, New York • (516) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 817-5500

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 060798-E84905
ISSUE DATE: July 6, 1998

Issued to: Square D Company
3700 6th Street S. W.
Cedar Rapids, IA 52404-3069, USA

Report Reference: E84905, November 21, 1988

This is to Certify that representative samples of: Molded Case Circuit Breakers
Catalog Number prefix QOB

Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 489, Molded Case Circuit Breakers and Circuit Breaker Enclosures

Additional Information: These are two and three pole circuit breakers, with the following ratings:
Two pole 150A, 22,000 AIC, 120/240Vac, 1Phase
Three pole 110A through 150A, 22,000, 240Vac 3Phase

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" (UL); the word "Listed"; a control number (may be alphanumeric) assigned by UL; and the product or category name (product identifier), as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: Lawrence Smith
Lawrence Smith
Underwriters Laboratories Inc.

Review Engineer: Jeffrey Hidaka
Jeffrey Hidaka
Underwriters Laboratories Inc.