



Catalog Number: 8872-GSC1  
Item Description: N1 SCREW CVR GUTTER  
UPC Code: 784572109674


Brand Name: Milbank  
Type: Lay In Wireway  
Application: Wireway  
Standard: UL Listed, Type 1  
Cover Type: Screw Cover  
Enclosure: Indoor Enclosure  
Nominal Cross Section: 8x8  
Straight Section Length: 72  
Material: Steel with Powder Coat Finish  
Finish: ANSI 61 Gray  
Knockouts: True





*Utility requirements may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must always be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.*

PREFIX	LABEL NO.
NONE	1002943
RC-	1125051

ITEM	QTY.	PART NUMBER	DESCRIPTION
1	1	(SEE CHART)	BACK
2	2	(SEE CHART)	PLATE/COVER
3	1	(SEE CHART)	UL LABEL, WIREWAY
4	1	1002913	LABEL, RATING
5	8	1001290	SCREW, 10-32 X 5/16
6	3	1002880	BAG ASSY (NOT SHOWN)





SUFFIX	BACK #	COVER #
-SU	1001458	1002277
-SUC	1129061	1129027
-SO	1129062	1099561
-SUNK	1010741	1002277
-NK	1099562	1099561
-SUNKC	1129063	1129027



SUFFIX	FINISH
NONE	PAINTED
-NP	NOT PAINTED

NOTE:  
1. PLACE BAG ASSY INSIDE ENCLOSURE. (NOT SHOWN)

NEMA DWG.: #551

Material:	14 GA. - SEE CHART	 General Offices: Kansas City, MO
Finish:	SEE CHART	
Tolerances: Unless Specified Otherwise X.X ±.1 X.XX ±.03 X.XXX ±.015 X° ±2°		Title:
 Third Angle Projection		Catalog No.:
Scale: NTS Drawn By: DY		Customer:
Checked By: Approved By:		Drawing No.:
		Date:
		Sheet 1 of 1

F	8-30-07	DELETE 1002277; ADD 1011827; 1001290 QTY. WAS 4;	G	7/25/11	1002880 (3) WAS (4) (ECO #21026)	D.F.
		ADD BACK & COVER CHART (ECO. 15946)	DL			