



Catalog Number: 6672-GSC1  
Item Description: N1 SCREW CVR GUTTER  
UPC Code: 784572108288


Brand Name: Milbank  
Type: Lay In Wireway  
Application: Wireway  
Standard: UL Listed, Type 1  
Cover Type: Screw Cover  
Enclosure: Indoor Enclosure  
Nominal Cross Section: 6x6  
Straight Section Length: 72  
Material: Steel with Powder Coat Finish  
Finish: ANSI 61 Gray  
Knockouts: True





*Utility requirements may vary. Always consult the serving utility for their requirements prior to ordering or installing this equipment. This product must always be installed by a licensed electrician. Installation of this equipment may require local electrical inspector approval.*

PREFIX	LABEL NO.
NONE	1002943
RC-	1125051

ITEM	QTY.	PART NUMBER	DESCRIPTION
1	1	(SEE CHART)	BACK
2	2	(SEE CHART)	PLATE/COVER
3	1	(SEE CHART)	UL LABEL, WIREWAY
4	1	1002942	LABEL, RATING
5	9	1001290	SCREW, 10-32 X 5/16
6	3	1002880	BAG ASSY (NOT SHOWN)





SUFFIX	BACK #	COVER #
-SU	1001461	1003288
-SUC	1128957	1128933
-SO	1128958	1011818
-SUNK	1010733	1003288
-NK	1010731	1011818
-SUNKC	1128959	1128933



SUFFIX	FINISH
NONE	PAINTED
-NP	NOT PAINTED

NOTE:  
1. PLACE BAG ASSY INSIDE ENCLOSURE. (NOT SHOWN)

NEMA DWG. #570

Material:	16 GA. - SEE CHART	 General Offices: Kansas City, MO	
Finish:	SEE CHART		
Tolerances: Unless Specified Otherwise X.X ±.1 X.XX ±.03 X.XXX ±.015 X° ±2°		Title: SCREW COVER WIREWAY 6 x 6 x 72, TYPE 1 NEMA ENCLOSURE	
 Third Angle Projection		Catalog No.: 6672-GSC1	
		Customer: MILBANK STANDARD	
		Drawing No.: <b>1003056</b>	
Scale:	NTS	Date:	
Drawn By:	DY	Approved By:	
Checked By:		Sheet	
DL	8-28-07	IT. 1001290 QTY. W 4 ECO. 15946	1 of 1
D.F.	6/29/11	1002880 (3) WAS (4) (ECO #20905)	

E	8-28-07	ADDED BACK & COVER CHART & REMOVED			IT. 1001290 QTY. W 4 ECO. 15946	DL
		IT. 1002301 & ADDED 1011897 &	F	6/29/11	1002880 (3) WAS (4) (ECO #20905)	D.F.